



Central Weber Sewer Improvement District

January 31, 2022

Tammy Aydelotte
Weber County Planning Commission
2380 Washington Blvd #240, Ogden, UT 84401

SUBJECT: Summerset Farms Ph. 3
Sanitary Sewer Service
Will Serve Letter

Tammy,

At the request of Ed Green Construction we have reviewed a subdivision plan for Summerset Farms Ph. 3 located at approximate address 2300 S 3650 W Taylor, Utah of 11 residential lots. We offer the following comments regarding Central Weber providing sanitary sewer service.

1. At this current time, Central Weber has the capacity to treat the sanitary sewer flow from this subdivision. Inasmuch as system demand continuously changes with growth, this assessment is valid for three (3) years from the date issued on this letter.
2. If any connection is made directly into Central Weber's line the connection must be inspected by Central Weber while the work is being done. A minimum of 48-hour notice for inspection shall be given to Central Weber prior to any work associated with the connection.
3. Central Weber will not take ownership or responsibility for the condition, ownership or maintenance of the proposed sanitary sewer lines (gravity or pressure) or system that will be installed to serve this subdivision.
4. The connection of any sump pumps (or similar type pumps) to the sanitary sewer system is prohibited during or after construction. Central Weber's Wastewater Control Rules and Regulations state:

Prohibited Discharge into Sanitary Sewer. No person shall discharge or cause or make a connection which will allow discharge of any storm water, surface water, groundwater, roof water runoff or subsurface drainage to any sanitary sewer.

5. The entire parcel of property to be served will need to be annexed into the district prior to any connection to the District's line. This annexation must be complete before the sale of any lots in



Central Weber Sewer Improvement District

the subdivision.

Impact fees will need to be paid prior to the issuance of any building permits.

If you have any further questions or need additional information, please let us know.

Sincerely,

Clay Marriott

Construction Manager

CC: Kevin Hall

Lori Blake

Attachments: Plat with Application SS3