



Mike Zimmerman Well Service, LC

• *Waterwells • Residential, Commercial, Industrial • Pump Installation and Service* •

P.O. Box 8 • Magna, Utah 84044 • 801-250-1400 • FAX 801-250-1047 • E-mail: Zdrillerteam@yahoo.com

To Whom it may concern:

Water Right E6424 WIN #447711

48hr pump test starting on 7-15-2023 at 12:30pm pump off at 1:00pm 7-17-2023.
Well pumped at 15gpm, static water level 53, pumping level after 48 hours 135'.

Water Right 35-14219 WIN #447630

48hr pump test starting on 7-17-2023 at 2:00pm, pump shut off on 7-19-2023 at
4:30pm, static water level 52, pumping level after 48 hours 147' at 20gpm.

Thank you

Mike Zimmerman