

PLAN REVIEW NOTICE

Weber-Morgan Health Department has reviewed plans and specifications for the remodel of the following food service establishment:

Establishment Name: Sawasdee Thai in Eden

Establishment Address 2612 N HWY162 #4

City/State/Zip Code: Eden, UT 84310

Current Date: 11.30.23

Owner/Manager/Developer: Lane Rubin

Plans Have Been Approved: Yes

The plans have been approved under the following stipulation(s):

- Emails and additional documentation provided to this office adequately address the plan review questions and issues raised by the Weber-Morgan Health Department.
- Any equipment that is connected to a water line that does not have adequate backflow protection must be equipped with backflow protection that meets the standards of the Utah amendments to the 2018 International Plumbing Code (i.e. RPZ, 1022s on all incoming water lines to beverage dispensers, etc.)
- Air gaps are required for drain lines of fridges, 3- compartment sinks or any other sinks that are used for food prep.
- Any items of concern in the Risk and Operational Assessments will be addressed prior to opening.
- This facility must pass a pre-opening inspection before opening.
- Cat 2 permit fee will need to be paid before pre-opening can be scheduled.
- Basement not finished can only be used for storage, if facility plans to prep food it will need to meet the standards of R392-100 Food Service Sanitation Rule.

Chemical Dispenser Note:

- If chemical dispensers are installed they must be installed in accordance with the Utah Plumbing Code (2018 IPC with Utah Amendments).
- Chemical dispensers shall connect to a separate, dedicated water supply separate from any sink faucet.
- Chemical dispensers connected to a water line must be tested and labeled with an ASME A112.1.2 or ASME A112.1.3 sticker indicating the dispensing unit acts as an air gap. A dispensing system approved only as ASSE 1055B is not an approved air gap in Utah.

Please address any questions and information to:

Cynthia Rudh
Weber-Morgan Health Department
477 23rd Street
Ogden, UT 84401
Telephone: (801) 399-7144
Fax number: (801) 399-7160