



Weber Fire District

Plan Review

Date: July 2, 2014

Project Name: Dale Satterhwaite Subdivision/ Flag Lots

Project Address: 900 South 7900 East, Huntsville

Contractor/Contact: Dale Satterhwate 801-629-2704

Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Subdivision			\$50.00
				\$0.00
				\$0.00
				\$0.00
			Total Due	\$50.00

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

REVIEW STATUS: APPROVED WITH CONDITIONS

SPECIFIC COMMENTS:

1. Fire Hydrant(s): There must be at least one new fire hydrant provided within 250 feet of the building lots. In discussion with Mr. Satterthwaite, it was indicated that a single hydrant located near the entrance to lots 1 and 5 would meet the distance requirements to all the building lots. This hydrant is not indicated on the plat, but must be provided.
2. Fire Flow: All structures over 5000 sq. ft. which do not meet the fire flow requirements, shall be equipped with an NFPA 13D compliant fire sprinkler system. For more information regarding fire flow, please contact Fire Marshal Thueson at 801-782-3580.
3. Provide a temporary address marker at the building site during construction.
4. Fire Access roads must meet the requirements of the County. Roads shall have a and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load.
5. Radius on all corners shall be a minimum of 28'-0".
6. Dead end fire apparatus access roads in excess of 150 feet in length shall be provide with an approved area for turning around fire apparatus constructed with the same requirements as the roads.

General Requirements:

- Roads and bridges shall be designed, constructed and maintained to support an



Weber Fire District

Plan Review

imposed load of 75,000 lbs.

- All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson
Fire Marshal

cc: File