



- (A) 1750 gallon Septic tank
- (B) Distribution Box
- (C) 4 inch PVC perforated pipe
- (D) 5 bedroom Home total of 520 lf of trench covering a minimum of 1500 sq of leach area.
- (E) Sewer Clean out
- (F) porta a john location
- (G) Concrete Wash Out
- (H) Silt Fence
- (I) Excavated soils storage area

NOTE:
max trench depth into original soil is 12 inches

Property Address
Land Parcel Id Number #21-088-0002
Property Owners
Tom and Ellen Crabtree
System Design
5 bedrooms with a application rate of .5
1750 Gallon septic tank
1500 sq feet of leach area
500 lf of trench minimum.
Designed By
James Green
00614-OSP-3
May 14 2014