
ENGINEERING ADDENDUM

The following letter is provided by Solid Structural Engineering for the Huntsville B&B at

1188 South Old Trappers Loop Road
Huntsville, UT 84317

Changes listed in this letter supersede information contained in the original structural drawings or previous letters. Only items listed in this letter are permitted to be changed from the original design or previous letters. Any alterations to this letter are prohibited.

The piers for exterior spot footings were not inspected. Photos show that all piers most likely only have (1) #3 tie at the top of the pier instead of the (3) #3 ties shown in detail 'AG'.

- (1) #3 ties within the top 5" of the piers are permitted instead of the (3) #3 ties shown in detail 'AG'. This change is permitted for all instances of detail 'AG'.
- The builder shall meet all inspection requirements of the building official to verify existing rebar meets the minimum requirements.

