


R:\2319 - WOLF CREEK WATER AND SEWER\2104- EAST WELL\DESIGN\DWG\WCWSID EAST WELL DESIGN.DWG

- 1.7 LANDSCAPE ROCK
- 1.8 WEED BARRIER FABRIC
- ACCESS ROAD - SEE DETAIL ON SHEET C5
- 1.5 UTBC 10" DEPTH
- WELL ACCESS 1.9
- 3" PULVERIZED PAVEMENT BASE COURSE ON 1.5 6" UTBC

Notes
 1. Well pump operation requires pumping for 5 minutes each time pump runs. Flow rate of 0.635 CFS will be pumped to waste.



SITE PLAN
 WCWSID - EAST WELL
 5650 E ELKHORN DR
 EDEN, WEBER, UTAH

GARDNER ENGINEERING
 CIVIL & LAND PLANNING
 MUNICIPAL & LAND SURVEYING
 1580 W 2100S, WEST HAVEN, UT 84405
 P 801.476.0202 F 801.476.0066



C1
 15

Date:	4-11-2024
Scale:	1" = 40'
Designed:	JKH
Drafted:	JKH
Checked:	MDD

Revisions	Description	Date
1	REV 1 CUP	4-11-2024

