



Weber Fire District

Plan Review

Date: August 28, 2014

Project Name: Hipwell Subdivision

Project Address: 3800 N 3900 W, Weber County Ut 84404

Contractor/Contact: Chris DeHerrera

Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Residential			\$50.00
Residential Impact Fee	328.15		1	\$328.15
				\$0.00
				\$0.00
			Total Due	\$378.15

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

REVIEW STATUS: MAKE CORRECTIONS

SPECIFIC COMMENTS:

1. Fire Hydrant(s):
 - a. On the road improvement document, an existing fire hydrant is indicated but there is no reference to this existing hydrant on the subdivision plat.
 - b. As there will be a new structure built on Lot 1, there must be at least fire hydrant within 250 feet of the building lot and the maximum spacing between hydrants in a residential area is 500 ft. Indicate on the plat the location of the existing hydrant.
 - c. If any construction is to take place on Lot 2, then an additional hydrant will be needed.
2. Fire Flow: All structures over 5000 sq. ft. which do not meet the fire flow requirements, shall be equipped with an NFPA 13D compliant fire sprinkler system. For more information regarding fire flow, please contact Fire Marshal Thueson at 801-782-3580.
3. Provide a temporary address marker at the building site during construction.
4. Dead end fire apparatus access roads in excess of 150 feet in length shall be provide with an approved area for turning around fire apparatus constructed with the same requirements as the roads.
5. Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
6. All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.



Weber Fire District

Plan Review

7. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
8. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
9. Fire department apparatus access is required for each lot.

A written response for this review is required.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson
Fire Marshal

cc: File