



2023 W. 1300 N.
Farr West, UT 84404
(801) 782-3580
Fax (801) 782-3582

PLAN REVIEW

Date: October 16, 2014

Project Name: GSL/Compass Minerals Thickener TH0001 Replacement

Project Address: 765 N 10500 W Weber County Utah 84404

Contractor/Contact: Brian Lloyd 801-305-4247

Fee(s):

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Commercial			\$100.00
				\$0.00
				\$0.00
				\$0.00
Total Due				\$100.00

Fee Notice:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: Weber Fire District.

Status: APPROVED

Specific Comments:

1. Provide a 2a10bc rated fire extinguisher within the new building. Travel distance to an extinguisher is not to exceed 75 feet.
2. Any emergency shut down switches shall be clearly marked and identified.
3. Shaftways shall be identified as outlined by section 316 of the International Fire Code.

General Comments (These comments apply to all occupancies):

There shall be an address (building number/name) on the building or on a sign visible from the street. The address numbers, whether on the building or the sign, shall be a minimum of four inches in height with a 1/2 inch stroke and be in contrasting colors from the background.

Provide a working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height in front of electrical service equipment. If the electrical equipment is wider than 30 inches, the working space shall not be less than the width of the equipment. There shall be no storage within the designated working space.

Gas meters shall be protected from vehicular damage. If the gas meter is in a traffic area, bollards shall be provided as per the International Fire Code.

Every effort has been made to provide a complete and thorough review of these plans. This review DOES NOT relieve the owner, contractor and/or developer from compliance with any and all applicable codes, and standards.

Any change or revision of this plan will render this review void and will require submittal of the new, or revised, layout for fire department review. If you have any questions, please contact me at 801-782-3580.

Brandon Thueson
Fire Marshal

cc: File