



## Central Weber Sewer Improvement District

November 25, 2024

Felix Lleverino  
Weber County Planning Commission  
2380 Washington Blvd #240, Ogden, UT 84401

SUBJECT: Bitton  
Sanitary Sewer Service  
Will Serve Letter

Felix:

We have reviewed the request of Pat Burns to provide sanitary sewer treatment services to the subdivision called Bitton located at approximate address 800 S. 4100 W. proposed 87 residential lots. We offer the following comments regarding Central Weber Sewer Improvement District ('the District') providing sanitary sewer service.

1. At this time, the District has the capacity to treat the sanitary sewer flow from this subdivision. Inasmuch as the system demand continuously changes with growth, this assessment is valid for three (3) years from the date issued on this letter.
2. If any connection is made directly into the District's facilities the connection must be constructed in accordance with District standards and must be inspected by the District while the work is being done. A minimum of 48-hour notice for inspection shall be given to the District prior to any work associated with the connection.
3. Central Weber Sewer Improvement District is a wholesale wastewater treatment provider to Weber County. Connection to the sewer system must be through a retail provider, which we understand to be Weber County. The District will not take responsibility for the condition, ownership or maintenance of the proposed sanitary sewer lines (gravity or pressure) or system that will be installed to serve this subdivision.
4. The connection of any sump pumps (or similar type pumps) to the sanitary sewer system is prohibited during or after construction. The District's Wastewater Control Rules and Regulations state:



## Central Weber Sewer Improvement District

*Prohibited Discharge into Sanitary Sewer. No person shall discharge or cause or make a connection which would allow to be discharged any storm water, surface water, groundwater, roof water runoff or subsurface drainage to any sanitary sewer.*

5. **The entire parcel of property to be served must be annexed into the Central Weber Sewer Improvement District prior to any sewer service connection or connection to the District's facilities.** This annexation must be complete before the sale of any lots in the subdivision. Annexation into the District is permitted by the District's Board of Trustees. This will serve letter is a statement of available capacity and does not guarantee board approval of annexation.
6. Impact fees must be paid no later than the issuance of any building permits.

If you have any further questions or need additional information, please let us know.

Sincerely,

Clayton Marriott

Digitally signed by Clayton Marriott  
DN: C=US,  
E=Claym@centralweber.com,  
O="CENTRAL WEBER SEWER",  
OU="CENTRAL WEBER SEWER",  
CN=Clayton Marriott  
Reason: I am the author of this  
document  
Date: 2024.11.25 12:48:27-0700'

Clay Marriott

Project Manager

CC: Chad Meyerhoffer, Weber County  
Kevin Hall, Central Weber Sewer  
Paige Spencer  
Pat Burns