



Weber Fire District

Plan Review

Date: November 17, 2015

Project Name: Sterling Automotive Solutions

Project Address: 4930 E 2550 N. Eden

Contractor/Contact: Justin Pack, Ogden Valley Homes | 801-814-7433

Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Commercial Site			\$50.00
Commercial Impact Fee	Commerical	244.97		\$3,552.06
				\$0.00
				\$0.00
Total Due				\$3,602.06

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

REVIEW STATUS: APPROVED

SPECIFIC COMMENTS:

1. Fire Hydrant(s): A new fire hydrant was installed near the building to increase fire flow capacity.
2. Provide a temporary address marker at the building site during construction.
3. Fire Access roads to any property shall have a minimum clear width of 20 feet (face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load.
4. Radius on all corners shall be a minimum of 28'-0".
5. Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
6. All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
7. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
8. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all



Weber Fire District

Plan Review

applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson
Fire Marshal

cc: File