



# Weber Fire District

## Plan Review

**Date:** March 25, 2015

**Project Name:** Sandhill Crane Cluster Subdivision –REVIEW #2

**Project Address:** 2500 North 5700 East Eden Utah 84136

**Contractor/Contact:** Blake Wahlen [wahlen@q.com](mailto:wahlen@q.com) 801-510-6136

**Fees:**

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Subdivision 1-30 Lots			\$50.00
				\$0.00
				\$0.00
				\$0.00
			<b>Total Due</b>	<b>\$50.00</b>

### FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

---

### REVIEW STATUS: MAKE CORRECTIONS

### SPECIFIC COMMENTS:

1. The cul-de-sac shown is now the proper size.
2. Fire Hydrant(s): The fire hydrants that were shown spaced appropriately on the original submittal have now been left off of the most current submittal. Verify that the hydrants are intended to be installed by showing on the plan.
3. Fire Flow: All structures over 5000 sq. ft. which do not meet the fire flow requirements, shall be equipped with an NFPA 13D compliant fire sprinkler system. For more information regarding fire flow, please contact Fire Marshal Thueson at 801-782-3580.
4. Provide a temporary address marker at the building site during construction.
5. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.
6. Radius on all corners shall be a minimum of 28'-0".
7. Dead end fire apparatus access roads in excess of 150 feet in length shall be provide with an approved area for turning around fire apparatus constructed with the same requirements as the roads.
8. Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
9. All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
10. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for



# Weber Fire District

## Plan Review

height, width and imposed loads as permanent roads.

11. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.

**A written response for this review is required.**

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson  
Fire Marshal

cc: File