

Department of Environmental Quality

Alan Matheson Executive Director

DIVISION OF DRINKING WATER Kenneth H. Bousfield, P.E.

June 7, 2016

Cal Welling Eden Waterworks 5402 East 2200 North Eden, Utah 84310

Dear Mr. Welling:

Subject: Plan Approval, Water Line Replacement and New Water Line Serving Sandhill Crane

Subdivision, System #29005, File #10426

The Division of Drinking Water (the Division) received the plans and specifications for the Sandhill Crane Subdivision project from Steve Waldrip with Eden Waterworks on May 12. Written review comments were provided to Steve Waldrip on May 16. The Division received the revised plans and specifications on May 25.

Our understanding of the project is the abandoning of approximately 1,014 feet of 4-inch water line and replacing it with 8-inch PVC C-900 water line as well as installing an additional 500 feet through the new Sandhill Crane Subdivision.

We have completed our review of the plans and specifications, stamped and signed by J. Nate Reeve, P.E. and dated May 24, and find they basically comply with the applicable portions of Utah's Administrative Rules for Public Drinking Water Systems in R309. On this basis, **the plans for the Sandhill Subdivision project are hereby approved**.

This approval pertains to construction only. An Operating Permit must be obtained from the Director before the Sandhill Subdivision project may be put in service. A checklist outlining the items required for operating permit issuance is enclosed for your information.

Approvals or permits from the local authority or the county may be necessary before beginning construction of this project. As the project proceeds, notice of any changes in the approved design, as well as any change affecting the quantity or quality of the delivered water, must be submitted to the Division. Because we may conduct interim and final inspections, please notify us when construction begins.

This approval must be renewed if construction has not begun or if substantial equipment has not been ordered within one year of the date of this letter.

If you have any questions regarding this letter, please contact Gary Kobzeff, of this office, at (801) 536-0099, or Ying-Ying Macauley, Engineering Section Manager, of this office, at (801) 536-4188.

Sincerely,

Kenneth H. Bousfield, P.E.

Director

GK/yym/mdb/hb

Enclosure — Operating Permit Checklist

cc: Louis Cooper, Health Director, Weber-Morgan Health Department, lcooper@co.weber.ut.us Chris Cave, P.E., Reeve & Associates, ccave@reeve-assoc.com
Thom Summers, Eden Waterworks, edenwaterworks@gmail.com
Gary Kobzeff, Division of Drinking Water, email address

DDW-2016-011734.docx

Utah Division of Drinking Water — Checklist for Issuing Operating Permits

Water Sys	stem Name: System Number:
Project D	escription: File Number:
operating service prentire wat [In this car distribution]	below must be submitted to the Division and found to be acceptable prior to permit issuance. However, distribution lines without booster pumps may be placed into rior to submitting all of the items if a professional engineer (PE) responsible for the ter system has been identified to the Director and has received items 1 through 4 below. See, a public water system will submit all items needed to obtain an Operating Permit for each in system project after the new water lines have been placed into service as determined by the tem's designated PE.]
be	ertification of Rule Conformance by a PE that all conditions of Plan Approval have sen accomplished, and if applicable, changes made during construction were in informance with rules R309-500 through 550
sp	s-built or record drawings incorporating all changes to approved plans and ecifications, unless no changes were made to the previously submitted and approved e-construction drawings
□ 3. Co	onfirmation that as-built or record drawings have been received by the water system
	vidence that bacteriological samples have been collected to verify proper flushing and sinfection in accordance with the appropriate ANSI/AWWA Standards:
	ANSI/AWWA C651-14 AWWA Standard for Disinfecting Water Mains
	Two consecutive sample sets at least 16 hours apart, none positive (every 1200 feet, end-of-line, each branch, etc.)
	ANSI/AWWA C652-11 AWWA Standard for Disinfection of Water-Storage Facilities
	One or more samples, none positive
	ANSI/AWWA C653-13 AWWA Standard for Disinfection of Water Treatment Plants
	Two consecutive samples per unit, none positive, no less than 30 minutes apart
	ANSI/AWWA C654-13 AWWA Standard for Disinfection of Wells
	Two consecutive samples, none positive, no less than 30 minutes apart
da sh	ater quality data, where appropriate [Guidance: Include appropriate raw and finished water to that demonstrate satisfactory performance of the new treatment facility. Storage tank water all be analyzed for residual volatile organic compounds after tank interior painting or reating.]
	applicable, all other documentation that may have been required during the plan review ocess
	applicable, confirmation that the water system owner has received the O&M manual r the new facility
□ 8. If	applicable, location data of new storage tank, treatment facility, or source