



PERMIT TO CONSTRUCT AN ONSITE WASTEWATER TREATMENT SYSTEM
ISSUED BY THE WEBER-MORGAN HEALTH DEPARTMENT
477 23rd Street, OGDEN, UTAH 84401



Permit No.: W102368

Issued: April 8, 2025

Expires: April 8, 2026

This is to certify that **MARK SPENCER** is hereby issued a permit to install an onsite wastewater treatment system for the property with the Property Identification Number **22-015-0088** with the following specifications and provisions:

Approximate construction site address: **3483 N RIVER DR, LIBERTY**

Lot: N/A of the N/A subdivision in **Weber** county Utah.

Water supply will be provided by: **WELL (PRIVATE)**.

Type of System will be **PACKED BED MEDIA SYSTEM** with an absorption area of **556 Sq. Ft.**

Septic tank capacity must be at least **1250** gallons. System is designed for a **3** bedroom home.

Maximum depth of trench bottoms must be limited to **18** inches from original ground surface.

***** IMPORTANT - PLEASE READ CAREFULLY *****

SIZED FOR MAXIMUM WATER USAGE OF 500 GPD.

MAXIMUM DEPTH TO BOTTOM OF TRENCH FROM ORIGINAL GROUND SURFACE IS 18".

THREE FOOT MAXIMUM BACKFILL OVER SEPTIC TANK.

MAINTAIN 100 FOOT SEPARATION FROM WELL HEAD.

OPERATION & MAINTENANCE REQUIRED BY LEVEL 3 STATE CERTIFIED PROVIDER.

WATER TIGHTNESS TEST REQUIRED. TANK MUSTBE FULL AT TIME OF INSPECTION.

Please provide the permit number and address when requesting the final inspection or any additional information regarding this system.
Final inspection to be completed prior to any backfilling of installed system.

This permit may be revoked or altered if the site is found to be in a flood hazard or other geologic hazard area. This permit is based on minimum design standards, and in no case does it guarantee against the failure of the installed system. The performance of the installed system is affected by many other factors, such as operation, maintenance, wastewater contents, etc., not addressed by the standards.

Ayda Kenley Lpk