

April 8, 2025

Mark Spencer  
1862 N 3900 W  
Ogden, Ut 84404

RE: **Private Well Approval at:**  
3483 N River Drive  
Liberty, UT 84310  
Parcel #22-015-0088

The application for approval of the above referenced well has been submitted for review to determine conformance to the Weber-Morgan District Health Department Regulations for Installation and Approval of Nonpublic Water System Serving 1-14 Connections.

The following have been submitted:

1. The Water Right Number: E6625 (35-14512)
2. Well driller license #527
3. The well is 200 feet deep with a "Non Coated Bentonite" seal to a depth of 35 feet.
4. The well yields 20 GPM with a 0-foot drawdown in 4 hrs.
5. The water samples for the partial inorganic analysis were submitted to Chemtech-Ford Laboratories on March 27, 2025. The water analysis was satisfactory.
6. A bacteriological water sample was collected by staff of this department on March 27, 2025. The water analysis was satisfactory.
7. This is not a shared well.

The required 100-foot protection zone around the well must be kept free from any septic tank absorption systems, garbage dumps, hazardous and toxic material storage or disposal sites, feedlots and other concentrated sources of pollution. We would recommend that a bacteriological sample be collected and submitted for analysis on an annual basis.

Based on compliance with the above requirements, the Health Department considers this an approved well for culinary purposes.

Please contact our office at (801) 399-7160 if you have further questions.

Sincerely,



Cynthia Rudh, LEHS II, MBA  
Division of Environmental Health