

4. If there is any painting of vehicles, the paint operations must conform to the International Fire Code (spray finish applications must conform to the applicable paint booth or spray room requirements).
5. The repair garage area must conform to section 2311 of the International Fire Code.
6. There shall be an address on the building or on a sign visible from the street. If the address is on a sign-monument the sign-monument shall meet the requirements of the appropriate city/county planning department. The address numbers, whether on the building or the sign, shall be a minimum of four inches in height with a 1/2 inch stroke and be in contrasting colors from the background.
7. Provide a working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height in front of electrical service equipment. If the electrical equipment is wider than 30 inches, the working space shall not be less than the width of the equipment. There shall be no storage within the designated working space.
8. Gas meters shall be protected from vehicular damage. If the gas meter is in a traffic area, bollards shall be provided as per the International Fire Code.

Every effort has been made to provide a complete and thorough review of these plans. This review DOES NOT relieve the owner, contractor and/or developer from compliance with any and all applicable codes, and standards.

Any change or revision of this plan will render this review void and will require submittal of the new, or revised, layout for fire department review. If you have any questions, please contact me at 801-782-3580.

Brandon Thueson
Fire Marshal

cc: File