



Weber Fire District

Plan Review

Date: June 2, 2015

Project Name: Falcone Residence

Project Address: 7947 E Hearthwood Dr Eden

Contractor/Contact: Cristiana Falcone 801-272-7111 danielle@amdarchitecture.com

Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Residential			\$50.00
Residential Impact Fee	328.15		1	\$328.15
				\$0.00
				\$0.00
			Total Due	\$378.15

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

REVIEW STATUS: APPROVED

SPECIFIC COMMENTS:

1. Fire suppression plans must be submitted for review. These may be a deferred submittal. Work on the fire suppression system may not begin prior to a permit being issued.
2. Provide a temporary address marker at the building site during construction.
3. Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
4. All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
5. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
6. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
7. Fire department apparatus access is required for each lot.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.



Weber Fire District

Plan Review

Reviewed by: Brandon Thueson
Fire Marshal

cc: File