

Weber Fire District

Plan Review

Date: October 19, 2016

Project Name: Mariani Residence Hillside Review Lot 5 -Review #2 **Project Address: 2337 Panorama Circle Liberty Utah 84310**

Contractor/Contact: Ryan Jones, Calute Homes

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District**.

REVIEW STATUS: APPROVED

NOTE: All comments from the previous review have been addressed. Per discussions with Ryan Jones the home will comply with the 2006 Wildland Urban Interface Code.

SPECIFIC COMMENTS:

- 1. Provide a temporary address marker at the building site during construction.
- 2. Fire Access via Driveways: Driveways serving no more than 5 residences shall have a minimum clear width of 16 feet with a minimum of 12 feet of drive-able surface (measured from face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000 pound load. Driveways in excess of 150 feet shall be provided with turn-arounds. Driveways exceeding 200 feet in length and less than 20 feet in width shall be provided with turnouts in addition to turnarounds. (See driveways- 2006 Wildland Urban Interface Code used as a reference for residential driveway requirements exceeding 150 feet in length). Roads and driveways shall also comply with City/County standards as applicable. *In cases of differing requirements, contact the Fire Marshal for clarification*.
- 3. All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- 4. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- 5. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson

Fire Marshal

cc: File