



November 9, 2011

Chad Meyerhoffer  
Weber County Engineering Dept.  
2380 Washington Blvd. Suite 240  
Ogden, UT 84401

***Subject: Powder Mountain Park/Ride***

Dear Mr. Meyerhoffer:

Below please find our response to your email dated November 1, 2011.

We appreciate your review and trust we have changed and/or clarified all of your comments referenced herein.

1. The property lines have been shown in relationship to the site.
2. Percolation test location and results have been shown on plan.
3. If the ground is frozen, the water will not percolate into the ground.
4. The plans have been updated to indicated the historical flow paths. If the ponds are to overflow, the stormwater would follow the historical flow path.
5. All signs shown on plans are existing signs to remain. Plans have been updated to indicate that signs are existing.
6. See attached permit.

If you have any questions, or we can be of further assistance, please let us know.

Sincerely,  
REEVE & ASSOCIATES, INC.

---

J. Nathan Reeve, PE, PSE  
Principal / President  
nreeve@reeve-assoc.com

---

Shane Taggart, E.I.T.  
Civil Engineer  
staggart@reeve-assoc.com

encs.

**Solutions You Can Build On™**

Civil Engineering • Land Planning • Structural Engineering • Landscape Architecture • Land Surveying • Construction Surveying  
4155 S. Harrison Blvd., Suite 310 • Ogden, Utah 84403 • Tel: 801-621-3100 • Fax: 801-621-2666  
ogden@reeve-assoc.com • reeve-assoc.com