



# Weber Fire District

## Plan Review

**Date:** July 6, 2016

**Project Name:** Diamond H Subdivision

**Project Address:** 3973 N 2975 W Ogden Utah 84404

**Contractor/Contact:** Tom Hadley 801-726-4014 [ttasHA21@gmail.com](mailto:ttasHA21@gmail.com)

**Fees:**

| Property Type          | Schedule Rates    | Square Foot Rate | Square Feet or Number of Res. Units | Total          |
|------------------------|-------------------|------------------|-------------------------------------|----------------|
| Type                   | Rate              | Rate/ Sq Ft      | Sq Ft or # of Units                 | Total          |
| Plan Review            | 2 Lot Subdivision |                  |                                     | \$50.00        |
| Residential Impact Fee | 328.15            |                  |                                     | \$0.00         |
|                        |                   |                  |                                     | \$0.00         |
|                        |                   |                  |                                     | \$0.00         |
|                        |                   |                  | <b>Total Due</b>                    | <b>\$50.00</b> |

### FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

### REVIEW STATUS: APPROVED WITH CONDITIONS

### SPECIFIC COMMENTS:

1. Fire Hydrant(s): Fire hydrant must be provided within 400 feet of the furthest most portion of a building or facility (see IFC 507.5.1). The maximum spacing between hydrants in a residential area is 500 ft.
2. Fire Flow: Fire flow for the subdivision is 1000 GPM. Homes larger than 10,000 Square feet may require fire suppression systems. For more information regarding fire flow, please contact Fire Marshal Thueson at 801-782-3580.
3. Provide a temporary address marker at the building site during construction.
4. Dead end fire apparatus access roads in excess of 150 feet in length shall be provide with an approved area for turning around fire apparatus constructed with the same requirements as the roads.

### General Requirements:

- Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- All required fire hydrants and water systems shall be installed, approved and fully



# Weber Fire District

## Plan Review

functional prior to any combustible construction.

- Fire department apparatus access is required for each lot.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson  
Fire Marshal

cc: File