



February 10, 2017

Weber County
ATTN: Chad Meyerhoffer
2380 Washington Blvd Suite #240
Ogden, Utah 84401

Re: WinCo #80 Cross Dock
SCJ Project #1832.04

Dear Chad Meyerhoffer:

In response to your comments dated November 8, 2016 are the following comments.

- 1. There is a concern with the detention pond and the high possibility of it being full of water all the time. We may want to meet on site when it is to be constructed to see if it will be an issue or not.***

The proposed stormwater facility has a bottom elevation of 4272.10 which is 0.43-feet above the base level elevation of 4271.53-feet in the Weber County stormwater facility. This will allow for the proposed stormwater facility to drain between storm events. Please see the updated drainage report dated January 2017.

- 2. The orifice on the existing site will need to be verified to make sure it is operating as it originally was designed to.***

A note has been added to the construction plans for the contractor to coordinate with Weber County on the inspection of the existing stormwater control structure. Please see sheet SD-01 of the construction plans.

- 3. There will need to be a Storm Water Maintenance Agreement with the Development.***

Attached please find the signed Storm Water Maintenance Agreement as requested.

- 4. A Storm Water Pollution Prevention Plan (SWPPP) is now required to be submitted for all new development where construction is required. The State now requires that a Utah Pollutant Discharge Elimination Systems (UPDES) permit be acquired for all new development. A copy of the permit needs to be submitted to the county before final approval. Permits can now be obtained online thru the Utah State Dept. of Environmental Quality at the following web site:.***

Attached please find a copy of the SWPPP and UPDES as requested for review and processing.

5. **A Storm Water Activity Permit will need to be obtained through our office before construction begins.** http://www1.co.weber.ut.us/mediawiki/images/5/56/Stormwater_Construction_Activity_Permit.pdf

Attached please find the signed Storm Water Activity Permit as requested.

Respectfully,
SCJ Alliance

A handwritten signature in blue ink, appearing to read "Brandon Johnson", written over a horizontal line.

Brandon Johnson, PE
Civil Engineering Manager

c:

Enclosure(s):