

---

## Engineering Review 2

**Project:** [Fairways at Wolf Creek Phase 4 & 5 Final Subdivision](#)  
**User:** [Braden Felix](#)  
**Department:** [Weber County Engineering Division](#)  
**Created:** 2017-01-31 16:34:21  
**Modified:** 2017-01-31 16:48:51

### Notes

---

I have had a chance to review the plan(s) and have the following comment(s):

1. The will-serve letter from Wolf Creek Water and Sewer Improvement District states they have the capacity to serve the project, but they don't list what services they can provide. Provide a letter stating the district can supply culinary, sanitary sewer, and irrigation for the subdivision.
2. In lot 67, provide a 20' wide storm drain easement instead of a 10'.

I have tried to address all items of concern from the Engineering Department. However, this review does not forego other items of concern that may come to this department's attention during additional reviews or during construction of improvements. If you have any comments or questions concerning this review, feel free to contact me.

© 2010–2017 Weber County **Planning** and **Engineering** Divisions.

Images, drawings, plats, elevations, renderings, site plans, et cetera on this site may be protected by copyright law. They are provided for viewing as a public service. Permission from the copyright holder should be obtained prior to any uses other than personal viewing; any other uses of these files may be copyright infringement.