

A

R

W

ENGINEERS

structural consultants


Structural Calculations

For

LPC – Upper System Tank

Project Number: 16194

August 31, 2016



Prepared by
ARW Engineers
1594 West Park Circle
Ogden, Utah 84404

Design Criteria

Snow Load: 100 psf (see spreadsheet)

Max Soil over Cover: 6" (75 psf)

Soil Bearing Pressure: 4000 psf

At Rest Horiz. Pressure: 57 pcf

Seismic Active Pressure: 46 pcf

Tank Geometry

Inside Diameter = 53'-0"

(4) interior columns spaced @ 17'-8" o.c.

Wall height = 16'-0"

Overflow @ 15'-6"



UTAH SNOW LOAD STUDY

Version Date: July 20, 2012 author: TAB Reviewed by: TMD
 Project: Liberty Upper System Tank
 Description:

Date: 8/17/2016
 Job#: 16194
 By: DLP

County: Weber

Po: 43 psf
 S: 63 psf/1000 ft.
 A₀: 4.5 ft./1000
 A: 5975 ft.
 Pg: 102.4 psf

Table No. 1608.1.2 (b) REQUIRED SNOW LOADS FOR SELECTED UTAH CITIES AND TOWNS ^{1,2}				
The following jurisdictions require design snow load values that differ from the equation in the Utah Snow Load Study.				
County	City	Elevation	Ground Snow Load (psf)	Roof Snow Load (psf) ⁶
Carbon	Price ³	5550	43	30
	All other County Locations ⁵	-	-	-
Davis	Fruit Heights ³	4500-4850	57	40
Emery	Green River ³	4070	36	25
Garfield	Panguitch ³	6600	43	30
Rich	Woodruff ³	6315	57	40
	Laketown ⁴	6000	57	40
	Garden City ⁵	-	-	-
	Randolph ⁴	6300	57	40
San Juan	Monticello ³	6820	50	35
Summit	Coalville ³	5600	86	60
	Kamas ⁴	6500	114	80
Tooele	Tooele ³	5100	43	30
Utah	Orem ³	4650	43	30
	Pleasant Grove ⁴	5000	43	30
	Provo ⁵	-	-	-
Wasatch	Heber ⁵	-	-	-
Washington	Leeds ³	3460	29	20
	Santa Clara ³	2850	21	15
	St. George ³	2750	21	15
	All other County Locations ⁵	-	-	-
Wayne	Loa ³	7080	43	30

¹The IBC Requires a minimum live load - See 1607.11.2
²This table is informational only in that actual site elevations may vary. Table is only valid if site elevation is within 100 feet of the listed elevation. Otherwise contact the local Building Official
³Values adopted from table VII of the Utah Snow Load Study
⁴Values based on site-specific study. Contact local Building Official for additional information.
⁵Contact Local Building Official
⁶Based on C_e=1.0, C_f=1.0, and I_s=1.0

Environmental Durability Factor

ACI 350-06 Section 9.2.6

$$S_d = \frac{\phi f_y}{\gamma f_s} \geq 1.0$$

$$\text{where } \gamma = \frac{\text{factored load}}{\text{unfactored load}}$$

$$f_s = 20 \text{ KSI}$$

(section 9.2.6.2)

* This applies to direct & hoop tensile stress.

Water

$$S_d = \frac{0.9 \cdot 60 \text{ KSI}}{1.4 \cdot 20 \text{ KSI}} = 1.93$$

Soil

$$S_d = \frac{0.9 \cdot 60 \text{ KSI}}{1.6 \cdot 20 \text{ KSI}} = 1.69$$

* Soil creates compression forces in hoop \therefore use $S_d = 1.0$ Flexural Stress

$$f_s = \frac{320}{B \sqrt{s^2 + 4(a + d_b/2)^2}}$$


[ACI 350-06 Eq. 10-4]

$$f_s = 20 \text{ KSI (conservative)}$$

$$S_d = \frac{0.90 \cdot 60 \text{ KSI}}{1.4 \cdot 20 \text{ KSI}} = 1.93$$

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 10/20/2010
 Reviewed By: TAB



Circular Concrete Tanks without Prestressing

(Based on the 1993 PCA Document)

Design Criteria

f_c	4500	psi
D_{tank}	53	ft
H_{tank}	16	ft
t_{wall}	12	in
Fluid Pressure	62.4	pcf
Soil Pressure	57	pcf
E_s	29000000	psi
E_c	3823676.24	psi
n	7.6	
Surcharge	175	pcf
Soil on Lid	1	ft
Load Factor		
$F_{liquid\ pressure}$	1.4	
$F_{soil\ pressure}$	1.6	
Environmental		
Durability Factor		
Flexure (liquid)	1.93	
Tension (liquid)	1.93	
Flexure (soil)	1.69	
Compression (soil)	1	
H^2/Dt	4.83	

Estimation of Tank Wall Thickness

Limit Ring Tension Stress in Concrete Wall from 7% to 12% of f_c

For given t and H^2/Dt , with a hinged base/free top (Table A-5)

Max Coefficient= 0.611 (Table A-5)

w_u 169 pcf

T_{max} 43647 lbs.

$T_{unfactored}$ 16154 lbs.

$A_s(req'd)$ 0.81 in²

$A_s(used)$ 0.88 in²

OK *#6 @ 12" o.c. Each Face*

$F_{l(conc)}$ 158 psi

This equates to 3.51 % of f_c
 Wall thickness is OK

Compression Check	
F_c	423
$0.33f_c$	1485
OK	

The Following Load Cases were used in Analysis:

- Load Case #1: Full of Water, No Lid, No Backfill
- Load Case #2: Empty, No Lid, w/Backfill
- Load Case #3: Empty, w/Lid, w/Backfill
- Load Case #4: Full of Water, w/Lid, Ignore Backfill

Load Case #1-Full of Water, No Lid, No Backfill

Assume Free Top/Hinged Base (Tables A-5 and A-7)

Effects of Possible outward movement will be handled by designing the entire portion of the wall for the maximum Ring Tension and Moment


Ring Force=(A-5 Coef.) w_uHR $w_uHR=$ 71488.4352

Moment =(A-7 Coef.) w_uH^3 $w_uH^3=$ 690605.2608

	A-5 Coef.	RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.004	-268	0	0
0.1H	0.118	8429	0.0000	12
0.2H	0.238	17018	0.0002	139
0.3H	0.358	25583	0.0008	532
0.4H	0.469	33528	0.0019	1304
0.5H	0.559	39970	0.0038	2618
0.6H	0.611	43647	0.0061	4241
0.7H	0.597	42679	0.0085	5865
0.8H	0.493	35279	0.0098	6773
0.9H	0.288	20556	0.0080	5551
Bottom	0.000	0	0	0

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD



Load Case #2-Empty, No Lid, w/ Backfill

Use Durability Coefficients as Noted Previous

Soil Over Lid= 1 ft
 ρ 175

Ring Force=(A-5 Coef.) w_u HR+(A-6 Coef.) ρ R

w_u HR= -74631
 ρ R= -14320.6

Moment=(A-7 Coef.)($w_u h^3 + \rho h^2$)

$w_u h^3 + \rho h^2 = -752447$

	A-5 Coef	RF (#)	A-6 Coef.	RF (#)	Total RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.004	280	0.996	-14266.8302	-13987	0	0
0.1H	0.118	-8799	1.018	-14577.0198	-23376	0.0000	-13
0.2H	0.238	-17766	1.038	-14865.5934	-32632	0.0002	-152
0.3H	0.358	-26708	1.058	-15149.3034	-41857	0.0008	-579
0.4H	0.469	-35002	1.069	-15308.7214	-50311	0.0019	-1421
0.5H	0.559	-41727	1.059	-15167.1366	-56894	0.0038	-2852
0.6H	0.611	-45566	1.011	-14471.6418	-60037	0.0061	-4621
0.7H	0.597	-44555	0.897	-12845.5782	-57400	0.0085	-6390
0.8H	0.493	-36830	0.693	-9931.201	-46761	0.0098	-7380
0.9H	0.288	-21460	0.388	-5549.908	-27010	0.0080	-6048
Bottom	0.000	0	0.000	0	0	0	0

Load Case #3-Empty, w/Lid, w/Backfill

Apply a shear force (V) @ top of wall to make Ring Tension = 0 @ top of Wall

When top of tank is free, Ring Force (LC#2) = -13987 #

At top of wall (0.0H) from table A-8, Coefficient= -8.07 #

Therefore, the shear force (V) required to produce zero ring force at the top of the tank=
 (Coef. A-8 @ 0.0H)(VR/H)=(Ring Force from LC#2)

Therefore

V= -1046 #
 VR/H= -1733 #

Delta_{RF}=Change in Ring Force Due to V applied @ the top of wall

Delta_{RF}=(A-8 Coef.)(VR/H)

Find the change in moment (Delta_{mom}) due to the V applied @ top.

If S_D for moment is less than S_D for compression, then V is reduced by (S_{DM}/S_{DC})


Delta_{mom}=(A-9 Coef.)VH

VH= -16742

	A-8 Coef.	Delta _{RF} (#)	LC#2 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC #2 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.071	13987	-13987	0	0	0	0	0
0.1H	-4.946	8571	-23376	-14805	0.0647	-1083	-13	-1096
0.2H	-2.475	4290	-32632	-28342	0.0797	-1334	-152	-1486
0.3H	-0.843	1460	-41857	-40397	0.0694	-1162	-579	-1741
0.4H	0.059	-102	-50311	-50413	0.0497	-832	-1421	-2253
0.5H	0.434	-753	-56894	-57647	0.0305	-511	-2852	-3364
0.6H	0.480	-831	-60037	-60868	0.0150	-252	-4621	-4873
0.7H	0.363	-629	-57400	-58030	0.0042	-70	-6390	-6460
0.8H	0.198	-344	-46761	-47104	-0.0027	45	-7380	-7335
0.9H	0.060	-104	-27010	-27114	-0.0075	126	-6048	-5922
Bottom	0.000	0	0	0	-0.0124	207	0	207

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD



Load Case #4-Full of Water, w/Lid, ignore Backfill

Add the effects of shear @ the top of the tank to LC #1

At the top of the wall - Coefficient from Table A-8= -8.07 #

(Coef. A-8 @ 0.0H)(VR/H) = (Ring Force from LC#1)

V= -20 #
 VR/H= -33 # (For Ring Force)
 VH= -321 # (For Moment)


	A-8 Coef.	Delta _{RF} (#)	LC#1 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC#1 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.07	268	-268	0	0	0	0	0
0.1H	-4.95	164	8429	8593	0.065	-21	12	-9
0.2H	-2.48	82	17018	17101	0.080	-26	139	114
0.3H	-0.84	28	25583	25611	0.069	-22	532	509
0.4H	0.06	-2	33528	33526	0.050	-16	1304	1288
0.5H	0.43	-14	39970	39956	0.031	-10	2618	2608
0.6H	0.48	-16	43647	43631	0.015	-5	4241	4237
0.7H	0.36	-12	42679	42667	0.004	-1	5865	5864
0.8H	0.20	-7	35279	35272	-0.003	1	6773	6774
0.9H	0.06	-2	20556	20554	-0.008	2	5551	5553
Bottom	0	0	0	0	-0.012	4	0	4

Envelope of Ring Forces

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	-268	-13987	0	0	0	-13987
0.1H	8429	-23376	-14805	8593	8593	-23376
0.2H	17018	-32632	-28342	17101	17101	-32632
0.3H	25583	-41857	-40397	25611	25611	-41857
0.4H	33528	-50311	-50413	33526	33528	-50413
0.5H	39970	-56894	-57647	39956	39970	-57647
0.6H	43647	-60037	-60868	43631	43647	-60868
0.7H	42679	-57400	-58030	42667	42679	-58030
0.8H	35279	-46761	-47104	35272	35279	-47104
0.9H	20556	-27010	-27114	20554	20556	-27114
Bottom	0	0	0	0	0	0

	Tension	Compression
Bottom	0	0
0.9H	21	-27
0.8H	35	-47
0.7H	43	-58
0.6H	44	-61
0.5H	40	-58
0.4H	34	-50
0.3H	26	-42
0.2H	17	-33
0.1H	9	-23
Top	0	-14

Controls (handwritten note with arrow pointing to the -61 value in the 0.6H row)



Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD




Envelope of Moments

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	0	0	0	0	0	0
0.1H	12	-13	-1096	-9	12	-1096
0.2H	139	-152	-1486	114	139	-1486
0.3H	532	-579	-1741	509	532	-1741
0.4H	1304	-1421	-2253	1288	1304	-2253
0.5H	2618	-2852	-3364	2608	2618	-3364
0.6H	4241	-4621	-4873	4237	4241	-4873
0.7H	5865	-6390	-6460	5864	5865	-6460
0.8H	6773	-7380	-7335	6774	6774	-7380
0.9H	5551	-6048	-5922	5553	5553	-6048
Bottom	0	0	207	4	207	0

	Tension O.F.	Tension I.F.
Bottom	0	0
0.9H	6	-6
0.8H	7	-7
0.7H	6	-6
0.6H	4	-5
0.5H	3	-3
0.4H	1	-2
0.3H	1	-2
0.2H	0	-1
0.1H	0	-1
Top	0	0

Controls ←



Design of Wall SteelRing Steel

- Compression

$$f_c = C/A = 61^k / 12 \cdot 12 = 424 \text{ psi}$$

$$C = 61^k @ 0.6H$$

$$1/3 (4500 \text{ psi}) = 1500 \text{ psi} > 473 \text{ psi} \therefore \text{OK}$$

- Tension

$$A_s = 44.0^k / 0.9 \cdot 60 \text{ KSI} = 0.82 \text{ IN}^2$$

$$\text{USE \#6 BARS @ 12" o.c. Each Face} = 0.88 \text{ IN}^2 > 0.82 \text{ IN}^2 \therefore \text{OK}$$

$$\text{minimum shrinkage steel} = 0.005 (12") (12") = 0.72 \text{ IN}^2/\text{ft}$$

$$\text{USE \#6 BARS @ 12" o.c. Each Face over full height of wall}$$

F_t OK (see Spreadsheet)

Design of Wall Steel

Moment Reinforcing

- Steel at Interior Face

$$M_u = 7 \text{ K-ft}$$

$$\frac{M_u}{\phi f'_c b d^2} = \frac{7 \text{ K-ft} \cdot 12}{0.9 \cdot 4.5 \cdot 12'' \cdot 9.5''} = 0.019151$$

$$\omega = 0.0200 \quad [\text{Table A-20}]$$

$$\rho = 0.0200 \cdot \frac{4.5}{60} = 0.0015$$

$$\rho_{\min} (\text{temp. shrinkage}) = 0.003$$

$$A_{s,\min} = 0.003 \cdot 12 \cdot 12 = 0.432 \text{ in}^2/\text{ft} \quad (\text{Each Face})$$

$$A_{s,\min} (\text{flexure}) = \frac{3\sqrt{4500}}{60000} \cdot 12'' \cdot 9.5'' = 0.383 \text{ in}^2/\text{ft}$$

OR

$$A_{s,\min} (\text{flexure}) = \frac{200 \cdot 12'' \cdot 9.5''}{60,000} = 0.38 \text{ in}^2/\text{ft}$$

USE #6 BAR @ 12" o.c. E.F.

$$0.44 \text{ in}^2/\text{ft} > 0.432 \text{ in}^2/\text{ft} \quad \therefore \text{OK}$$

* This steel also works for exterior face

Shear Strength of Wall

$$\phi V_c = 0.75 \cdot 2 \cdot \sqrt{4500} \cdot 12'' \cdot 9.5'' = 11.4^{\text{K}}$$

$$V_u = 0.236 (1.6) (62.4 \text{ pcf}) (16^2) \cdot 1.69 = 10.2^{\text{K}} < 11.4^{\text{K}} \quad \therefore \text{OK}$$

↑

coeff. PCA Table A-12

CONCRETE LAP SPICE TABLE

CONCRETE DEVELOPMENT AND LAP SPICE DESIGN TABLE

BASED ON CHAPTER 12 OF THE 2011 ACI 318
 Author: Matt McBride

Version: June 17, 2013

Concrete Properties

- $\psi_t = 1.0$ For horizontal reinforcement placed such that more than 12 in. of fresh concrete is cast below the development length or splice (i.e. Top Splice) = 1.3 - Otherwise = 1.0
- $\psi_b = 1.0$ For Epoxy-coated bars or wires with cover less than $3d_b$, or clear spacing less than $6d_b = 1.5$ - For all other Epoxy-coated bars or wires = 1.2 - Otherwise = 1.0
- $\lambda = 1.0$ When Light-weight Aggregate Concrete is used = 0.75 - Otherwise = 1.0
- $\psi_s = 1.0$ For No. 6 smaller bars and deformed wires = 0.8 - Otherwise = 1.0

$$f_y = \frac{\text{Rebar Properties}}{60000} \text{ psi}$$

Bar Location	Concrete		CONCRETE REINFORCING DEVELOPMENT & SPICE LENGTHS																												
			BAR SIZE																												
			#3		#4		#5		#6		#7		#8		#9		#10		#11		#14		#18								
Type	Strength	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}						
Vert. Wall Bars, Fill on Metal Deck	NWC	3000 psi	17	22	8	22	29	8	28	36	10	33	43	12	48	62	13	55	72	15	62	81	17	69	19	76	30	96	38	124	49
Horiz. Wall Bars, Footing Top Bars	NWC	3000 psi	17	22	8	22	29	8	28	36	10	33	43	12	48	62	13	55	72	15	62	81	17	69	19	76	30	96	38	124	49
Beam Bottom Bars, Column Bars	NWC	3000 psi	17	22	8	22	29	11	28	36	14	33	43	16	48	62	19	55	72	22	62	81	25	69	27	76	30	96	38	124	49
Footing Bottom Bars	NWC	3000 psi	12	16	8	14	18	8	17	22	10	20	26	12	29	38	13	33	43	15	37	48	17	42	19	46	30				
Beam Top Bars	NWC	3000 psi	22	29	8	29	38	11	36	47	14	43	56	16	63	82	19	72	94	22	81	105	25	90	27	98	30	125	38	161	49
Slab on Grade	NWC	3000 psi	12	16	8	14	18	8	17	22	10	20	26	12	32	42	13	42	55	15	53	69	17	69	19	76	30				

Bar Location	Concrete		CONCRETE REINFORCING DEVELOPMENT & SPICE LENGTHS																												
			BAR SIZE																												
			#3		#4		#5		#6		#7		#8		#9		#10		#11		#14		#18								
Type	Strength	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}	l_d	l_{dh}	l_s	l_{sh}						
Vert. Wall Bars, Fill on Metal Deck	NWC	4000 psi	15	20	7	19	25	7	24	31	8	29	38	10	42	55	12	48	62	13	54	70	15	60	17	66	26	84	33	107	43
Horiz. Wall Bars, Footing Top Bars	NWC	4000 psi	15	20	7	19	25	7	24	31	8	29	38	10	42	55	12	48	62	13	54	70	15	60	17	66	26	84	33	107	43
Beam Bottom Bars, Column Bars	NWC	4000 psi	15	20	7	19	25	9	24	31	12	29	38	14	42	55	17	48	62	19	54	70	21	60	24	66	26	84	33	107	43
Footing Bottom Bars	NWC	4000 psi	12	16	7	12	16	7	15	20	8	18	23	10	25	33	12	29	38	13	33	43	15	36	17	40	26				
Beam Top Bars	NWC	4000 psi	19	25	7	25	33	9	31	40	12	37	48	14	54	70	17	62	81	19	70	91	21	78	24	85	26	108	33	139	43
Slab on Grade	NWC	4000 psi	12	16	7	12	16	7	15	20	8	18	23	10	28	36	12	36	47	13	46	60	15	60	17	66	26				

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS

Bar Location	Concrete		BAR SIZE																																
			#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}			
Vert. Wall Bars, Fill on Metal Deck	Type	Strength	14	18	7	18	23	6	23	30	8	27	35	9	40	52	11	45	59	13	51	66	14	56	16	62	25	79	31	101	40				
Horiz. Wall Bars, Footing Top Bars	NWC	4500 psi	14	18	7	18	23	6	23	30	8	27	35	9	40	52	11	45	59	13	51	66	14	56	16	62	25	79	31	101	40				
Beam Bottom Bars, Column Bars	NWC	4500 psi	14	18	7	18	23	9	23	30	11	27	35	13	40	52	16	45	59	18	51	66	20	56	22	62	25	79	31	101	40				
Footing Bottom Bars	NWC	4500 psi	12	16	7	12	16	6	14	18	8	17	22	9	24	31	11	27	35	13	31	40	14	34	16	37	25								
Beam Top Bars	NWC	4500 psi	18	23	7	24	31	9	30	39	11	35	46	13	51	66	16	59	77	18	66	86	20	73	22	80	25	102	31	131	40				
Slab on Grade	NWC	4500 psi	12	16	7	12	16	6	14	18	8	17	22	9	27	35	11	34	44	13	44	57	14	56	16	62	25								

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS

Bar Location	Concrete		BAR SIZE																																
			#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}	l _d	l _s	l _{dh}			
Vert. Wall Bars, Fill on Metal Deck	Type	Strength	13	17	6	17	22	6	22	29	7	26	34	9	38	49	10	43	56	12	48	63	13	54	15	59	23	75	30	96	38				
Horiz. Wall Bars, Footing Top Bars	NWC	5000 psi	13	17	6	17	22	6	22	29	7	26	34	9	38	49	10	43	56	12	48	63	13	54	15	59	23	75	30	96	38				
Beam Bottom Bars, Column Bars	NWC	5000 psi	13	17	6	17	22	8	22	29	11	26	34	13	38	49	15	43	56	17	48	63	19	54	21	59	23	75	30	96	38				
Footing Bottom Bars	NWC	5000 psi	12	16	6	12	16	6	13	17	7	16	21	9	23	30	10	26	34	12	29	38	13	32	15	36	23								
Beam Top Bars	NWC	5000 psi	17	22	6	23	30	8	28	36	11	34	44	13	49	64	15	56	73	17	63	83	19	69	21	76	23	97	30	125	38				
Slab on Grade	NWC	5000 psi	12	16	6	12	16	6	13	17	7	16	21	9	25	33	10	32	42	12	41	54	13	54	15	59	23								

CONCRETE LAP SPICE TABLE

JOB TITLE: LPC - Upper System Tank - Horizontal Wall Reinforcement
 BUILDING LOCATION : Liberty, UT

Horizontal Wall Reinforcement

CONCRETE DEVELOPMENT AND LAP SPICE DESIGN TABLE

BASED ON CHAPTER 12 OF THE 2011 ACI 318
 Author: Matt McBride

Concrete Properties

- $\psi_t = 1.3$ For horizontal reinforcement placed such that more than 12 in. of fresh concrete is cast below the development length or splice (i.e. Top Splice) = 1.3 - Otherwise = 1.0
- $\psi_e = 1.0$ For Epoxy-coated bars or wires with cover less than 3db, or clear spacing less than 6db = 1.5 - For all other Epoxy-coated bars or wires = 1.2 - Otherwise = 1.0
- $\lambda = 1.0$ When Light-weight Aggregate Concrete is used = 0.75 - Otherwise = 1.0
- $\psi_s = 1.0$ For No. 6 smaller bars and deformed wires = 0.8 - Otherwise = 1.0

Rebar Properties
 $f_y = 60000$ psi

CONCRETE REINFORCING DEVELOPMENT & SPICE LENGTHS

Bar Location	Concrete		BAR SIZE																												
			#3		#4		#5		#6		#7		#8		#9		#10		#11		#14		#18								
			l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}							
Vert. Wall Bars, Fill on Metal Deck	Type	Strength	22	29	8	38	8	36	47	10	43	56	12	63	82	13	72	94	15	81	105	17	90	19	98	30	125	38	161	49	
Horiz. Wall Bars, Footing Top Bars	NWC	3000 psi	22	29	8	38	8	36	47	10	43	56	12	63	82	13	72	94	15	81	105	17	90	19	98	30	125	38	161	49	
Beam Bottom Bars, Column Bars	NWC	3000 psi	22	29	8	38	11	36	47	14	43	56	16	63	82	19	72	94	22	81	105	25	90	27	98	30	125	38	161	49	
Footing Bottom Bars	NWC	3000 psi	13	17	8	23	8	22	29	10	26	34	12	38	49	13	43	56	15	49	64	17	54	19	59	30					
Beam Top Bars	NWC	3000 psi	28	36	8	49	11	47	61	14	56	73	16	81	105	19	93	121	22	105	137	25	116	27	128	30	162	38	209	49	
Slab on Grade	NWC	3000 psi	13	17	8	23	8	22	29	10	26	34	12	42	55	13	54	70	15	69	90	17	90	19	98	30					

CONCRETE REINFORCING DEVELOPMENT & SPICE LENGTHS

Bar Location	Concrete		BAR SIZE																												
			#3		#4		#5		#6		#7		#8		#9		#10		#11		#14		#18								
			l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}	l_d	l_{eh}							
Vert. Wall Bars, Fill on Metal Deck	Type	Strength	19	25	7	33	7	31	40	8	37	48	10	54	70	12	62	81	13	70	91	15	78	17	85	26	108	33	139	43	
Horiz. Wall Bars, Footing Top Bars	NWC	4000 psi	19	25	7	33	7	31	40	8	37	48	10	54	70	12	62	81	13	70	91	15	78	17	85	26	108	33	139	43	
Beam Bottom Bars, Column Bars	NWC	4000 psi	19	25	7	33	9	31	40	12	37	48	14	54	70	17	62	81	19	70	91	21	78	24	85	26	108	33	139	43	
Footing Bottom Bars	NWC	4000 psi	12	16	7	20	7	19	25	8	23	30	10	33	43	12	37	48	13	42	55	15	47	17	51	26					
Beam Top Bars	NWC	4000 psi	25	33	7	43	9	41	53	12	49	64	14	71	92	17	81	105	19	91	118	21	101	24	111	26	141	33	181	43	
Slab on Grade	NWC	4000 psi	12	16	7	20	7	19	25	8	23	30	10	36	47	12	47	61	13	60	78	15	78	17	85	26					

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS

Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}			
Vert. Wall Bars, Fill on Metal Deck	NWC	4500 psi	18	23	7	24	31	6	30	39	8	35	46	9	51	66	11	59	77	13	66	86	14	73	16	80	25	102	31	131	40				
Horiz. Wall Bars, Footing Top Bars	NWC	4500 psi	18	23	7	24	31	6	30	39	8	35	46	9	51	66	11	59	77	13	66	86	14	73	16	80	25	102	31	131	40				
Beam Bottom Bars, Column Bars	NWC	4500 psi	18	23	7	24	31	9	30	39	11	35	46	13	51	66	16	59	77	18	66	86	20	73	22	80	25	102	31	131	40				
Footing Bottom Bars	NWC	4500 psi	12	16	7	14	18	6	18	23	8	21	27	9	31	40	11	35	46	13	40	52	14	44	16	48	25								
Beam Top Bars	NWC	4500 psi	23	30	7	31	40	9	38	49	11	46	60	13	67	87	16	76	99	18	86	112	20	95	22	104	25	133	31	171	40				
Slab on Grade	NWC	4500 psi	12	16	7	14	18	6	18	23	8	21	27	9	34	44	11	44	57	13	57	74	14	73	16	80	25								

CONCRETE REINFORCING DEVELOPMENT & SPLICE LENGTHS

Bar Location	Concrete		BAR SIZE																																
	Type	Strength	#3			#4			#5			#6			#7			#8			#9			#10			#11			#14			#18		
			l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}	l _d	l _s	l _{eh}			
Vert. Wall Bars, Fill on Metal Deck	NWC	5000 psi	17	22	6	23	30	6	28	36	7	34	44	9	49	64	10	56	73	12	63	83	13	69	15	76	23	97	30	125	38				
Horiz. Wall Bars, Footing Top Bars	NWC	5000 psi	17	22	6	23	30	6	28	36	7	34	44	9	49	64	10	56	73	12	63	83	13	69	15	76	23	97	30	125	38				
Beam Bottom Bars, Column Bars	NWC	5000 psi	17	22	6	23	30	8	28	36	11	34	44	13	49	64	15	56	73	17	63	83	19	69	21	76	23	97	30	125	38				
Footing Bottom Bars	NWC	5000 psi	12	16	6	14	18	6	17	22	7	20	26	9	29	38	10	34	44	12	38	48	13	42	15	46	23								
Beam Top Bars	NWC	5000 psi	22	29	6	29	38	8	36	47	11	44	57	13	63	82	15	72	94	17	81	101	19	90	21	99	23	126	30	162	38				
Slab on Grade	NWC	5000 psi	12	16	6	14	18	6	17	22	7	20	26	9	33	43	10	42	55	12	54	74	13	69	15	76	23								

Tank Lid Design


$$DL: 150 \text{ pcf } (8''/12) + 15 \text{ psf} + 75 \text{ psf} = 190 \text{ psf}$$

Snow: 100 psf

↑
soil

* SEE SPREADSHEET

USE 8" SLAB w/ 4" drop panels that are 6'x6'



Concrete Water Tank - Roof Design

8/23/2016
9:46:06 AM

Version Date: 10/28/10 Author TAB
Job Title LPC - Upper System Tank Job # 16194

ENGINEERS
structural consultants

Roof Slab Design

Min Thickness

Slab Span	17.667 ft	Est. Column Thickness	16 in
h_{min}	5.94 in		
Use Slab Thickness	8 in	d	5.5 in
$f'c$	4500 psi	f_y	60 ksi

Loads

Dead Load	115 psf
Live Load	0 psf
Soil Load	75 psf
Snow Load	100 psf
W_U	388 psf

Shear Capacity of Slab

Round Column Dim	16 in	
b_o	67.5442 in	
V_U	121.104 kips	
ϕV_C (No Drop Panel)	74.7616 kips	NG Use Drop Panel
Drop Panel Dimension	6 ft square	
New b_o	310 in	
ϕV_C Drop Panel	343.125 kips	Ok
Drop Panel Thickness	4 in	
b_o	80.1106 in	
ϕV_C	153.159 kips	Ok

$$\text{min thickness} = \frac{2l}{33} = 6.43''$$

\therefore 8" slab is OK [ACI 350 9.5.3.2]

Flexural Design by Direct Design Method Of ACI 318

l_2	17.667 ft	S_d	1.93
l_n	16.3337 ft	Strip Width	8.833 ft
M_O	228.598 K-ft		
Exterior Span M^+ factor	0.63	Exterior M^+ factored Moment	144.02 k-ft
Exterior Span M^- factor	0.75	Exterior M^- factored Moment	171.45 k-ft
Interior Span M^+ factor	0.35	Interior M^+ factored Moment	80.009 k-ft
Interior Span M^- factor	0.65	Interior M^- factored Moment	148.59 k-ft

Col Strip Factored Mom.

M^+	0.6
Exterior M^-	0.75
Interior M^-	0.75

Mid Strip Factored Mom

	0.4
	0.25
	0.25

Exterior Positive Moment

Column Strip	166.771 k-ft
Moment per foot of width	18.8805 k-ft/ft
Mu/ϕ	20.9783 k-ft/ft
Mu/ϕ	251.74 k-in/ft
A_s	0.84838 in ²
a	1.10899
#4 Bar Spacing	2.83 in oc
#5 Bar Spacing	4.38 in oc
#6 Bar Spacing	6.22 in oc
#7 Bar Spacing	8.49 in oc
#8 Bar Spacing	11.17 in oc

Middle Strip	111.18 k-ft
Moment per foot of width	12.587 k-ft/ft
Mu/ϕ	13.986 k-ft/ft
Mu/ϕ	167.83 k-in/ft
A_s	0.5437 in ²
a	0.7107
#4 Bar Spacing	4.41 in oc
#5 Bar Spacing	6.84 in oc
#6 Bar Spacing	9.71 in oc
#7 Bar Spacing	13.24 in oc
#8 Bar Spacing	17.44 in oc

Exterior Negative Moment

Enter new d for Col strip 9.5

Column Strip	248.171 k-ft
Moment per foot of width	28.0959 k-ft/ft
Mu/ϕ	31.2177 k-ft/ft
Mu/ϕ	374.613 k-in/ft
A_s	0.68997 in ²
a	0.90192
#4 Bar Spacing	3.48 in oc
#5 Bar Spacing	5.39 in oc
#6 Bar Spacing	7.65 in oc
#7 Bar Spacing	10.44 in oc
#8 Bar Spacing	13.74 in oc

Middle Strip	82.724 k-ft
Moment per foot of width	9.3653 k-ft/ft
Mu/ϕ	10.406 k-ft/ft
Mu/ϕ	124.87 k-in/ft
A_s	0.3971 in ²
a	0.5191
#4 Bar Spacing	6.04 in oc
#5 Bar Spacing	9.37 in oc
#6 Bar Spacing	13.30 in oc
#7 Bar Spacing	18.13 in oc
#8 Bar Spacing	23.87 in oc

Interior Positive Moment

Column Strip 92.6507 k-ft
Moment per foot of width 10.4892 k-ft/ft
Mu/φ 11.6546 k-ft/ft
Mu/φ 139.855 k-in/ft
As 0.44761 in²
a 0.58512
#4 Bar Spacing 5.36 in oc
#5 Bar Spacing 8.31 in oc
#6 Bar Spacing 11.80 in oc
#7 Bar Spacing 16.09 in oc
#8 Bar Spacing 21.18 in oc

Middle Strip 61.767 k-ft
Moment per foot of width 6.9928 k-ft/ft
Mu/φ 7.7697 k-ft/ft
Mu/φ 93.237 k-in/ft
As 0.2927 in²
a 0.3826
#4 Bar Spacing 8.20 in oc
#5 Bar Spacing 12.71 in oc
#6 Bar Spacing 18.04 in oc
#7 Bar Spacing 24.60 in oc
#8 Bar Spacing 32.39 in oc

Interior Negative Moment

Enter new d for Col strip 9.5 in
Column Strip 215.082 k-ft
Moment per foot of width 24.3498 k-ft/ft
Mu/φ 27.0553 k-ft/ft
Mu/φ 324.664 k-in/ft
As 0.59385 in²
a 0.77627
#4 Bar Spacing 4.04 in oc
#5 Bar Spacing 6.26 in oc
#6 Bar Spacing 8.89 in oc
#7 Bar Spacing 12.12 in oc
#8 Bar Spacing 15.96 in oc

Middle Strip 71.694 k-ft
Moment per foot of width 8.1166 k-ft/ft
Mu/φ 9.0184 k-ft/ft
Mu/φ 108.22 k-in/ft
As 0.3418 in²
a 0.4468
#4 Bar Spacing 7.02 in oc
#5 Bar Spacing 10.88 in oc
#6 Bar Spacing 15.45 in oc
#7 Bar Spacing 21.06 in oc
#8 Bar Spacing 27.73 in oc

How Far past support must negative moment reinf. Extend?

Column Strip	5.39011 ft	Use	6 ft
Middle Strip	3.59341 ft	Use	4 ft

Column Design

Loads on Column uses PCA Table A-13 coeff. = 1.320

$$\text{Dead Load} = 115 \text{ psf } (17'-8'')^2 (1 + 0.2 \cdot 0.712) (1.320) = 54.2^k$$

$$\text{Snow Load} = 100 \text{ psf } (17'-8'')^2 (1.320) = 41.2^k$$

$$\text{Soil} = 75 \text{ psf } (17'-8'')^2 (1 + 0.2 \cdot 0.712) (1.320) = 35.3^k$$

$$E = \pi (1.0) (62.4 \text{ lbs/ft}^3) (8''/12)^2 + 0.4 (0.712) (1.25) (\pi \cdot 150 \text{ pcf} \cdot (16''/12)^2 / 4) = 162 \text{ pcf}$$

* SEE ENERCALC SOLUTION

USE 16" ϕ column w/ (8) #5 Bars S.R. = 0.760

OR

USE 14" \square column w/ (8) #6 Bars S.R. = 0.857

* Transverse Reinf. (ACI 350 21.4.4)

$$P_s = 0.12 (4500) / 60,000 = 0.009$$

$$\text{Spacing} \Rightarrow 14''/4 = 3.5''$$

$$6 (3/4'') = 4.5''$$

$$S_x = 4 + \left(\frac{14 - 12}{3} \right) = 4.667''$$

PER 10.9.3 $A_g = \pi \cdot 16^2 / 4 = 201 \text{ in}^2$ $A_c = \pi \cdot 13.5^2 / 4 = 143 \text{ in}^2$


$$P_s = 0.45 \left(\frac{201}{143} - 1 \right) 4.5 / 60 = 0.0137$$

$$\text{Req'd pitch of \#3 spiral} = 0.0137 = \frac{0.11 (\pi) (13.5'')}{143.5} \quad S_{\text{req'd}} = 2.38''$$

$$\text{Req'd pitch of \#4 spiral} = 0.0137 = \frac{0.20 (\pi) (13.5'')}{143.5} \quad S_{\text{req'd}} = 4.32''$$

$$\text{Spacing of \#3 hoops} = 0.009 = \frac{0.11 (\pi) (13.5'')}{143.5} \quad S_{\text{req'd}} = 3.62''$$

USE #4 spiral w/ 4" pitch or #3 hoops @ 3 1/2" o.c.



Concrete Column

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Design - Circular

Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10
Load Combinations Used : ASCE 7-10

General Information


f_c : Concrete 28 day strength = 4.50 ksi
 E = 3,122.0 ksi
 Density = 150.0 pcf
 β = 0.8250
 f_y - Main Rebar = 60.0 ksi
 E - Main Rebar = 29,000.0 ksi
 Allow. Reinforcing Limits *ASTM A615 Bars Used*
 Min. Reinf. = 1.0 %
 Max. Reinf. = 8.0 %

Overall Column Height = 18.0 ft
 End Fixity Top & Bottom Pinned
 Brace condition for deflection (buckling) along columns :
 X-X (width) axis :
 Unbraced Length for X-X Axis buckling = 18.0 ft, $K = 1.0$
 Y-Y (depth) axis :
 Unbraced Length for X-X Axis buckling = 18.0 ft, $K = 1.0$

Column Cross Section

Column Dimensions : 16.0in Diameter, Column Edge to Rebar
 Edge Cover = 2.50in

Column Reinforcing : 8 - #5 bars



Entered loads are factored per load combinations specified by user.

Applied Loads

Column self weight included : 3,769.91 lbs * Dead Load Factor

AXIAL LOADS . . .

Axial Load at 18.0 ft above base, $X_{ecc} = 3.0in$, $Y_{ecc} = 3.0in$, $D = 54.20$, $S = 41.20$, $H = 35.30$ k

BENDING LOADS . . .

Lat. Uniform Load creating M_x -x, $E = 0.1620$ k/ft

DESIGN SUMMARY

Load Combination +1.20D+0.50L+1.60S+1.60H
 Location of max. above base 17.879 ft

Maximum Stress Ratio

Ratio = $(P_u^2 + M_u^2)^{.5} / (\phi P_n^2 + \phi M_n^2)^{.5}$ 0.760 : 1
 $P_u = 191.964$ k $\phi * P_n = 253.337$ k
 $M_u-x = -53.902$ k-ft $\phi * M_n-x = -70.966$ k-ft
 $M_u-y = -53.902$ k-ft $\phi * M_n-y = 70.966$ k-ft

M_u Angle = 45.0 deg

M_u at Angle = 76.229 k-ft ϕM_n at Angle = 100.351 k-ft

P_n & M_n values located at P_u - M_u vector intersection with capacity curve

Column Capacities . . .

P_{nmax} : Nominal Max. Compressive Axial Capacity 908.38 k
 P_{nmin} : Nominal Min. Tension Axial Capacity -148.80 k
 ϕP_n , max : Usable Compressive Axial Capacity 579.09 k
 ϕP_n , min : Usable Tension Axial Capacity -111.60 k

Maximum SERVICE Load Reactions . .

Top along Y-Y	1.815 k	Bottom along Y-Y	1.815 k
Top along X-X	2.438 k	Bottom along X-X	1.815 k

Maximum SERVICE Load Deflections . . .

Along Y-Y -0.1179 in at 10.510 ft above base
 for load combination : +D+S+H
 Along X-X -0.1179 in at 10.510 ft above base
 for load combination : +D+S+H

General Section Information . $\phi = 0.750$ $\beta = 0.8250$ $\theta = 0.850$

ρ : % Reinforcing 1.233 % Rebar % Ok
 Reinforcing Area 2.480 in²
 Concrete Area 201.062 in²

Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k		Bending Analysis k-ft							Utilization Ratio	
	X-X	Y-Y		P_u	$\phi * P_n$	δ_x	$\delta_x * M_{ux}$	δ_y	$\delta_y * M_{uy}$	Alpha (deg)	δM_u	ϕM_n	Ratio	
+1.40D+1.60H	Actual	Actual	17.88	137.64	294.86	1.000	-32.87	1.000	-32.87	45.000	46.48	99.99	0.465	



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 1:47PM

Concrete Column

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Design - Circular

Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k		Bending Analysis k-ft						Utilization Ratio	
	X-X	Y-Y		Pu	$\phi * Pn$	δx	$\delta x * Mux$	δy	$\delta y * Muy$	Alpha (deg)	δMu	ϕMn	Ratio
+1.20D+0.50Lr+1.60L+1.60H	Actual	Actual	17.88	126.04	294.86	1.000	-30.18	1.000	-30.18	45.000	42.68	99.99	0.427
+1.20D+1.60L+0.50S+1.60H	Actual	Actual	17.88	146.64	294.86	1.000	-35.29	1.000	-35.29	45.000	49.91	99.99	0.499
+1.20D+1.60Lr+0.50L+1.60H	Actual	Actual	17.88	126.04	294.86	1.000	-30.18	1.000	-30.18	45.000	42.68	99.99	0.427
+1.20D+1.60Lr+0.50W+1.60H	Actual	Actual	17.88	126.04	294.86	1.000	-30.18	1.000	-30.18	45.000	42.68	99.99	0.427
+1.20D+0.50L+1.60S+1.60H	Actual	Actual	17.88	191.96	253.34	1.158	-53.90	1.158	-53.90	45.000	76.23	100.35	0.760
+1.20D+1.60S+0.50W+1.60H	Actual	Actual	17.88	191.96	253.34	1.158	-53.90	1.158	-53.90	45.000	76.23	100.35	0.760
+1.20D+0.50Lr+0.50L+W+1.60H	Actual	Actual	17.88	126.04	294.86	1.000	-30.18	1.000	-30.18	45.000	42.68	99.99	0.427
+1.20D+0.50L+0.50S+W+1.60H	Actual	Actual	17.88	146.64	294.86	1.000	-35.29	1.000	-35.29	45.000	49.91	99.99	0.499
+1.20D+0.50L+0.20S+E+1.60H	Actual	Actual	17.88	134.28	230.99	1.509	-48.34	1.000	-32.22	45.000	58.10	100.03	0.581
+0.90D+W+0.90H	Actual	Actual	17.88	83.94	297.46	1.000	-20.00	1.000	-20.00	45.000	28.29	99.92	0.283
+0.90D+E+0.90H	Actual	Actual	17.88	83.94	262.93	1.267	-25.12	1.000	-20.00	45.000	32.11	100.39	0.320

Maximum Reactions


Note: Only non-zero reactions are listed.

Load Combination	Reaction along X-X Axis		Reaction along Y-Y Axis		Axial Reaction
	@ Base	@ Top	@ Base	@ Top	@ Base
+D+H	1.243	1.243 k	1.243	1.243 k	93.270 k
+D+L+H	1.243	1.243 k	1.243	1.243 k	93.270 k
+D+Lr+H	1.243	1.243 k	1.243	1.243 k	93.270 k
+D+S+H	1.815	1.815 k	1.815	1.815 k	134.470 k
+D+0.750Lr+0.750L+H	1.243	1.243 k	1.243	1.243 k	93.270 k
+D+0.750L+0.750S+H	1.672	1.672 k	1.672	1.672 k	124.170 k
+D+0.60W+H	1.243	1.243 k	1.243	1.243 k	93.270 k
+D+0.70E+H	1.243	1.243 k	0.222	2.264 k	93.270 k
+D+0.750Lr+0.750L+0.450W+H	1.243	1.243 k	1.243	1.243 k	93.270 k
+D+0.750L+0.750S+0.450W+H	1.672	1.672 k	1.672	1.672 k	124.170 k
+D+0.750L+0.750S+0.5250E+H	1.672	1.672 k	0.907	2.438 k	124.170 k
+0.60D+0.60W+0.60H	0.746	0.746 k	0.746	0.746 k	55.962 k
+0.60D+0.70E+0.60H	0.746	0.746 k	0.275	1.766 k	55.962 k
D Only	0.753	0.753 k	0.753	0.753 k	57.970 k
Lr Only		k		k	k
L Only		k		k	k
S Only	0.572	0.572 k	0.572	0.572 k	41.200 k
W Only		k		k	k
E Only		k	1.458	1.458 k	k
H Only	0.490	0.490 k	0.490	0.490 k	35.300 k

Maximum Moments

Note: Only non-zero reactions are listed.

Load Combination	Moment About X-X Axis		Moment About Y-Y Axis	
	@ Base	@ Top	@ Base	@ Top
+D+H				k-ft
+D+L+H				k-ft
+D+Lr+H				k-ft
+D+S+H				k-ft
+D+0.750Lr+0.750L+H				k-ft
+D+0.750L+0.750S+H				k-ft
+D+0.60W+H				k-ft
+D+0.70E+H				k-ft
+D+0.750Lr+0.750L+0.450W+H				k-ft
+D+0.750L+0.750S+0.450W+H				k-ft
+D+0.750L+0.750S+0.5250E+H				k-ft
+0.60D+0.60W+0.60H				k-ft
+0.60D+0.70E+0.60H				k-ft
D Only				k-ft
Lr Only				k-ft
L Only				k-ft
S Only				k-ft
W Only				k-ft
E Only				k-ft
H Only				k-ft



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 1:47PM

Concrete Column

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489



Licensee: ARW ENGINEERS

Description: Column Design - Circular


Maximum Deflections for Load Combinations

Load Combination	Max. X-X Deflection	Distance	Max. Y-Y Deflection	Distance
+D+H	-0.0807 in	10.510 ft	-0.081 in	10.510 ft
+D+L+H	-0.0807 in	10.510 ft	-0.081 in	10.510 ft
+D+Lr+H	-0.0807 in	10.510 ft	-0.081 in	10.510 ft
+D+S+H	-0.1179 in	10.510 ft	-0.118 in	10.510 ft
+D+0.750Lr+0.750L+H	-0.0807 in	10.510 ft	-0.081 in	10.510 ft
+D+0.750L+0.750S+H	-0.1086 in	10.510 ft	-0.109 in	10.510 ft
+D+0.60W+H	-0.0807 in	10.510 ft	-0.081 in	10.510 ft
+D+0.70E+H	-0.0807 in	10.510 ft	-0.055 in	11.114 ft
+D+0.750Lr+0.750L+0.450W+H	-0.0807 in	10.510 ft	-0.081 in	10.510 ft
+D+0.750L+0.750S+0.450W+H	-0.1086 in	10.510 ft	-0.109 in	10.510 ft
+D+0.750L+0.750S+0.5250E+H	-0.1086 in	10.510 ft	-0.089 in	10.752 ft
+0.60D+0.60W+0.60H	-0.0484 in	10.510 ft	-0.048 in	10.510 ft
+0.60D+0.70E+0.60H	-0.0484 in	10.510 ft	-0.023 in	12.081 ft
D Only	-0.0489 in	10.510 ft	-0.049 in	10.510 ft
Lr Only	0.0000 in	0.000 ft	0.000 in	0.000 ft
L Only	0.0000 in	0.000 ft	0.000 in	0.000 ft
S Only	-0.0372 in	10.510 ft	-0.037 in	10.510 ft
W Only	0.0000 in	0.000 ft	0.000 in	0.000 ft
E Only	0.0000 in	0.000 ft	0.039 in	9.060 ft
H Only	-0.0318 in	10.510 ft	-0.032 in	10.510 ft

Sketches



Interaction Diagrams



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 1:47PM

Concrete Column


projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489


Licensee: ARW ENGINEERS

Description: Column Design - Circular


Concrete Column P-M Interaction Diagram




Concrete Column P-M Interaction Diagram




Concrete Column P-M Interaction Diagram



Concrete Column P-M Interaction Diagram





ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 1:47PM

Concrete Column

jects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7


Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Design - Circular


Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-ft)




Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-ft)




Concrete Column P-M Interaction Diagram


Phi * Mn @ Alpha (k-ft)



Concrete Column P-M Interaction Diagram

Phi * Mn @ Alpha (k-ft)





ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 1:46PM

Concrete Column

jects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Design - Square

Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10

Load Combinations Used: ASCE 7-10

General Information

f_c : Concrete 28 day strength = 4.50 ksi
 E = 3,122.0 ksi
 Density = 150.0 pcf
 β = 0.8250
 f_y - Main Rebar = 60.0 ksi
 E - Main Rebar = 29,000.0 ksi
 Allow. Reinforcing Limits *ASTM A615 Bars Used*
 Min. Reinf. = 1.0 %
 Max. Reinf. = 8.0 %


Overall Column Height = 18.0 ft
 End Fixity Top & Bottom Pinned

Brace condition for deflection (buckling) along columns:
 X-X (width) axis:
 Unbraced Length for X-X Axis buckling = 18.0 ft, K = 1.0
 Y-Y (depth) axis:
 Unbraced Length for X-X Axis buckling = 18.0 ft, K = 1.0

Column Cross Section

Column Dimensions: 14.0in Square Column, Column Edge to Rebar Edge Cover = 2.0in

Column Reinforcing: 4 - #6 bars @ corners,, 1.0 - #6 bars top & bottom between corner bars, 1.0 - #6 bars left & right between corner bars



Applied Loads

Entered loads are factored per load combinations specified by user.

Column self weight included: 3,675.0 lbs * Dead Load Factor

AXIAL LOADS...

Axial Load at 18.0 ft above base, Xecc = 3.0in, Yecc = 3.0in, D = 54.20, S = 41.20, H = 35.30 k

BENDING LOADS...


Lat. Uniform Load creating Mx-x, E = 0.1620 k/ft

DESIGN SUMMARY

Load Combination	+1.20D+0.50L+1.60S+1.60H		Maximum SERVICE Load Reactions . .	
Location of max. above base	17.879 ft		Top along Y-Y	1.815 k
Maximum Stress Ratio	0.857 : 1		Top along X-X	2.438 k
Ratio = $(P_u^2 + M_u^2)^{.5} / (\Phi P_n^2 + \Phi M_n^2)^{.5}$			Bottom along Y-Y	1.815 k
P_u = 191.850 k	$\Phi * P_n$ = 224.157 k		Bottom along X-X	1.815 k
M_{u-x} = -54.118 k-ft	$\Phi * M_{n-x}$ = -62.840 k-ft		Maximum SERVICE Load Deflections . .	
M_{u-y} = -54.118 k-ft	$\Phi * M_{n-y}$ = 63.483 k-ft		Along Y-Y	-0.1184 in at 10.510 ft above base
M_u Angle = 45.0 deg			for load combination: +D+S+H	
M_u at Angle = 76.534 k-ft	ΦM_n at Angle = 89.329 k-ft		Along X-X	-0.1184 in at 10.510 ft above base
<i>P_n & M_n values located at P_u-M_u vector intersection with capacity curve</i>			for load combination: +D+S+H	
Column Capacities . . .			General Section Information . $\phi = 0.650$ $\beta = 0.8250$ $\theta = 0.80$	
P_{nmax} : Nominal Max. Compressive Axial Capacity	947.44 k		ρ : % Reinforcing	1.796 % Rebar % Ok
P_{nmin} : Nominal Min. Tension Axial Capacity	-211.20 k		Reinforcing Area	3.520 in ²
ϕP_n , max : Usable Compressive Axial Capacity	492.667 k		Concrete Area	196.0 in ²
ϕP_n , min : Usable Tension Axial Capacity	-137.280 k			

Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k		Bending Analysis k-ft						Utilization	
	X-X	Y-Y		P_u	$\phi * P_n$	δx	$\delta x * M_{ux}$	δy	$\delta y * M_{uy}$	Alpha (deg)	δM_u	ϕM_n	Ratio
+1.40D+1.60H	Actual	Actual	17.88	137.51	263.16	1.000	-32.87	1.000	-32.87	45.000	46.48	88.61	0.524



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 1:46PM

Concrete Column

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Design - Square

Governing Load Combination Results

Governing Factored Load Combination	Moment		Dist. from base ft	Axial Load k			Bending Analysis k-ft					Utilization Ratio	
	X-X	Y-Y		Pu	$\phi * Pn$	δx	$\delta x * Mu_x$	δy	$\delta y * Mu_y$	Alpha (deg)	δMu	ϕMn	Ratio
+1.20D+0.50Lr+1.60L+1.60H	Actual	Actual	17.88	125.93	260.68	1.000	-30.18	1.000	-30.18	45.000	42.68	88.69	0.481
+1.20D+1.60L+0.50S+1.60H	Actual	Actual	17.88	146.53	260.68	1.000	-35.29	1.000	-35.29	45.000	49.91	88.69	0.563
+1.20D+1.60Lr+0.50L+1.60H	Actual	Actual	17.88	125.93	260.68	1.000	-30.18	1.000	-30.18	45.000	42.68	88.69	0.481
+1.20D+1.60Lr+0.50W+1.60H	Actual	Actual	17.88	125.93	260.68	1.000	-30.18	1.000	-30.18	45.000	42.68	88.69	0.481
+1.20D+0.50L+1.60S+1.60H	Actual	Actual	17.88	191.85	224.16	1.163	-54.12	1.163	-54.12	45.000	76.53	89.33	0.857
+1.20D+1.60S+0.50W+1.60H	Actual	Actual	17.88	191.85	224.16	1.163	-54.12	1.163	-54.12	45.000	76.53	89.33	0.857
+1.20D+0.50Lr+0.50L+W+1.60H	Actual	Actual	17.88	125.93	260.68	1.000	-30.18	1.000	-30.18	45.000	42.68	88.69	0.481
+1.20D+0.50L+0.50S+W+1.60H	Actual	Actual	17.88	146.53	260.68	1.000	-35.29	1.000	-35.29	45.000	49.91	88.69	0.563
+1.20D+0.50L+0.20S+E+1.60H	Actual	Actual	17.88	134.17	205.74	1.512	-48.44	1.000	-32.22	45.000	58.18	89.26	0.652
+0.90D+W+0.90H	Actual	Actual	17.88	83.86	263.16	1.000	-20.00	1.000	-20.00	45.000	28.29	88.61	0.319
+0.90D+E+0.90H	Actual	Actual	17.88	83.86	233.15	1.268	-25.15	1.000	-20.00	45.000	32.13	89.26	0.360

Note: Only non-zero reactions are listed.

Maximum Reactions

Load Combination	Reaction along X-X Axis		Reaction along Y-Y Axis		Axial Reaction @ Base
	@ Base	@ Top	@ Base	@ Top	
+D+H	1.243	1.243 k	1.243	1.243 k	93.175 k
+D+L+H	1.243	1.243 k	1.243	1.243 k	93.175 k
+D+Lr+H	1.243	1.243 k	1.243	1.243 k	93.175 k
+D+S+H	1.815	1.815 k	1.815	1.815 k	134.375 k
+D+0.750Lr+0.750L+H	1.243	1.243 k	1.243	1.243 k	93.175 k
+D+0.750L+0.750S+H	1.672	1.672 k	1.672	1.672 k	124.075 k
+D+0.60W+H	1.243	1.243 k	1.243	1.243 k	93.175 k
+D+0.70E+H	1.243	1.243 k	0.222	2.264 k	93.175 k
+D+0.750Lr+0.750L+0.450W+H	1.243	1.243 k	1.243	1.243 k	93.175 k
+D+0.750L+0.750S+0.450W+H	1.672	1.672 k	1.672	1.672 k	124.075 k
+D+0.750L+0.750S+0.5250E+H	1.672	1.672 k	0.907	2.438 k	124.075 k
+0.60D+0.60W+0.60H	0.746	0.746 k	0.746	0.746 k	55.905 k
+0.60D+0.70E+0.60H	0.746	0.746 k	0.275	1.766 k	55.905 k
D Only	0.753	0.753 k	0.753	0.753 k	57.875 k
Lr Only		k		k	k
L Only		k		k	k
S Only	0.572	0.572 k	0.572	0.572 k	41.200 k
W Only		k		k	k
E Only		k	1.458	1.458 k	k
H Only	0.490	0.490 k	0.490	0.490 k	35.300 k

Note: Only non-zero reactions are listed.

Maximum Moments

Load Combination	Moment About X-X Axis		Moment About Y-Y Axis	
	@ Base	@ Top	@ Base	@ Top
+D+H			k-ft	k-ft
+D+L+H			k-ft	k-ft
+D+Lr+H			k-ft	k-ft
+D+S+H			k-ft	k-ft
+D+0.750Lr+0.750L+H			k-ft	k-ft
+D+0.750L+0.750S+H			k-ft	k-ft
+D+0.60W+H			k-ft	k-ft
+D+0.70E+H			k-ft	k-ft
+D+0.750Lr+0.750L+0.450W+H			k-ft	k-ft
+D+0.750L+0.750S+0.450W+H			k-ft	k-ft
+D+0.750L+0.750S+0.5250E+H			k-ft	k-ft
+0.60D+0.60W+0.60H			k-ft	k-ft
+0.60D+0.70E+0.60H			k-ft	k-ft
D Only			k-ft	k-ft
Lr Only			k-ft	k-ft
L Only			k-ft	k-ft
S Only			k-ft	k-ft
W Only			k-ft	k-ft
E Only			k-ft	k-ft
H Only			k-ft	k-ft

Footing Design

$$DL: 54.2^k \cdot 1000 + 150 \text{ pcf} \left(\frac{16\frac{1}{2}}{12}\right)^2 / 4 \cdot \pi \cdot 18' = 58.0^k$$

$$SL: 41.2^k$$

$$\text{Soil: } 35.3^k$$

* SEE ENERCALL SOLUTION

USE F 6.5 X 18" thick w/ (6) #6 BARS Each Direction

Continuous Wall Footing

$$DL: 115 \text{ psf} \left(17\text{'-}8\frac{1}{2}\right) + 150 \text{ pcf} \left(\frac{12\frac{1}{2}}{12}\right) \left(17\text{'-}0\right) = 3570 \text{ plf}$$

$$SL: 100 \text{ psf} \left(17\text{'-}8\frac{1}{2}\right) = 885 \text{ plf}$$

$$\text{Soil: } 75 \text{ psf} \left(17\text{'-}8\frac{1}{2}\right) = 665 \text{ plf}$$

USE 3'-0" X 16" Footing w/ (3) #6 BARS

General Footing

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Footing

Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10
Load Combinations Used: ASCE 7-10

General Information

Material Properties

f'_c : Concrete 28 day strength	=	3.0 ksi
f_y : Rebar Yield	=	60.0 ksi
E_c : Concrete Elastic Modulus	=	3,122.0 ksi
Concrete Density	=	145.0 pcf
ϕ Values Flexure	=	0.90
Shear	=	0.750

Analysis Settings

Min Steel % Bending Reinf.	=	
Min Allow % Temp Reinf.	=	0.00180
Min. Overturning Safety Factor	=	1.0 : 1
Min. Sliding Safety Factor	=	1.0 : 1
Add Ftg Wt for Soil Pressure	:	Yes
Use ftg wt for stability, moments & shears	:	Yes
Add Pedestal Wt for Soil Pressure	:	No
Use Pedestal wt for stability, mom & shear	:	No

Soil Design Values

Allowable Soil Bearing	=	4.0 ksf
Increase Bearing By Footing Weight	=	No
Soil Passive Resistance (for Sliding)	=	250.0 pcf
Soil/Concrete Friction Coeff.	=	0.30

Increases based on footing Depth

Footing base depth below soil surface	=	ft
Allow press. increase per foot of depth when footing base is below	=	ksf ft

Increases based on footing plan dimension


Allowable pressure increase per foot of depth when max. length or width is greater than	=	ksf ft
---	---	-----------

Dimensions

Width parallel to X-X Axis	=	6.50 ft
Length parallel to Z-Z Axis	=	6.50 ft
Footing Thickness	=	18.0 in

Pedestal dimensions...

p_x : parallel to X-X Axis	=	14.0 in
p_z : parallel to Z-Z Axis	=	14.0 in
Height	=	in
Rebar Centerline to Edge of Concrete... at Bottom of footing	=	3.0 in



Reinforcing

Bars parallel to X-X Axis	=	
Number of Bars	=	6.0
Reinforcing Bar Size	=	# 6
Bars parallel to Z-Z Axis	=	
Number of Bars	=	6.0
Reinforcing Bar Size	=	# 6




Bandwidth Distribution Check (ACI 15.4.4.2)

Direction Requiring Closer Separation	=	n/a
# Bars required within zone	=	n/a
# Bars required on each side of zone	=	n/a

Applied Loads

	D	Lr	L	S	W	E	H
P: Column Load	=	58.0		41.20			35.30 k
OB: Overburden	=						ksf
M-xx	=						k-ft
M-zz	=						k-ft
V-x	=						k
V-z	=						k



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 23 AUG 2016, 9:29AM

General Footing

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_ipc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Column Footing

DESIGN SUMMARY

Design OK

	Min. Ratio	Item	Applied	Capacity	Governing Load Combination
PASS	0.8503	Soil Bearing	3.401 ksf	4.0 ksf	+D+S+H about Z-Z axis
PASS	n/a	Overturing - X-X	0.0 k-ft	0.0 k-ft	No Overturing
PASS	n/a	Overturing - Z-Z	0.0 k-ft	0.0 k-ft	No Overturing
PASS	n/a	Sliding - X-X	0.0 k	0.0 k	No Sliding
PASS	n/a	Sliding - Z-Z	0.0 k	0.0 k	No Sliding
PASS	n/a	Uplift	0.0 k	0.0 k	No Uplift
PASS	0.6053	Z Flexure (+X)	16.154 k-ft	26.688 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.6053	Z Flexure (-X)	16.154 k-ft	26.688 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.6053	X Flexure (+Z)	16.154 k-ft	26.688 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.6053	X Flexure (-Z)	16.154 k-ft	26.688 k-ft	+1.20D+0.50L+1.60S+1.60H
PASS	0.4328	1-way Shear (+X)	35.556 psi	82.158 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.4328	1-way Shear (-X)	35.556 psi	82.158 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.4328	1-way Shear (+Z)	35.556 psi	82.158 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.4328	1-way Shear (-Z)	35.556 psi	82.158 psi	+1.20D+0.50L+1.60S+1.60H
PASS	0.5813	2-way Punching	95.510 psi	164.317 psi	+1.20D+0.50L+1.60S+1.60H

Detailed Results

Soil Bearing

Rotation Axis & Load Combination...	Gross Allowable	Xeccc	Zeccc (in)	Actual Soil Bearing Stress @ Location				Actual / Allow Ratio
				Bottom, -Z	Top, +Z	Left, -X	Right, +X	
X-X, +D+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+L+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+Lr+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+S+H	4.0	n/a	0.0	3.401	3.401	n/a	n/a	0.850
X-X, +D+0.750Lr+0.750L+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+0.750L+0.750S+H	4.0	n/a	0.0	3.157	3.157	n/a	n/a	0.789
X-X, +D+0.60W+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+0.70E+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+0.750Lr+0.750L+0.450W+H	4.0	n/a	0.0	2.426	2.426	n/a	n/a	0.607
X-X, +D+0.750L+0.750S+0.450W+H	4.0	n/a	0.0	3.157	3.157	n/a	n/a	0.789
X-X, +D+0.750L+0.750S+0.5250E+H	4.0	n/a	0.0	3.157	3.157	n/a	n/a	0.789
X-X, +0.60D+0.60W+0.60H	4.0	n/a	0.0	1.455	1.455	n/a	n/a	0.364
X-X, +0.60D+0.70E+0.60H	4.0	n/a	0.0	1.455	1.455	n/a	n/a	0.364
Z-Z, +D+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+L+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+Lr+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+S+H	4.0	0.0	n/a	n/a	n/a	3.401	3.401	0.850
Z-Z, +D+0.750Lr+0.750L+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+0.750L+0.750S+H	4.0	0.0	n/a	n/a	n/a	3.157	3.157	0.789
Z-Z, +D+0.60W+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+0.70E+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+0.750Lr+0.750L+0.450W+H	4.0	0.0	n/a	n/a	n/a	2.426	2.426	0.607
Z-Z, +D+0.750L+0.750S+0.450W+H	4.0	0.0	n/a	n/a	n/a	3.157	3.157	0.789
Z-Z, +D+0.750L+0.750S+0.5250E+H	4.0	0.0	n/a	n/a	n/a	3.157	3.157	0.789
Z-Z, +0.60D+0.60W+0.60H	4.0	0.0	n/a	n/a	n/a	1.455	1.455	0.364
Z-Z, +0.60D+0.70E+0.60H	4.0	0.0	n/a	n/a	n/a	1.455	1.455	0.364


Overturing Stability

Rotation Axis & Load Combination...	Overturing Moment	Resisting Moment	Stability Ratio	Status
Footing Has NO Overturing				

Sliding Stability

Force Application Axis Load Combination...	Sliding Force	Resisting Force	Stability Ratio	Status
Footing Has NO Sliding				

All units k



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016, 3:05PM

Wall Footing

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee : ARW ENGINEERS

Description : Continuous Wall Footing

Code References

Calculations per ACI 318-11, IBC 2012, CBC 2013, ASCE 7-10
Load Combinations Used : ASCE 7-10

General Information

Material Properties

f'_c : Concrete 28 day strength	=	4.50 ksi
f_y : Rebar Yield	=	60.0 ksi
E_c : Concrete Elastic Modulus	=	3,122.0 ksi
Concrete Density	=	145.0 pcf
ϕ Values Flexure	=	0.90
Shear	=	0.750

Analysis Settings

Min Steel % Bending Reinf.	=	
Min Allow % Temp Reinf.	=	0.00180
Min. Overturning Safety Factor	=	1.0 : 1
Min. Sliding Safety Factor	=	1.0 : 1
AutoCalc Footing Weight as DL	:	Yes

Soil Design Values

Allowable Soil Bearing	=	4.0 ksf
Increase Bearing By Footing Weight	=	No
Soil Passive Resistance (for Sliding)	=	250.0 pcf
Soil/Concrete Friction Coeff.	=	0.30

Increases based on footing Depth

Reference Depth below Surface	=	0.0 ft
Allow. Pressure Increase per foot of depth when base footing is below	=	0.0 ksf
	=	0.0 ft

Increases based on footing Width

Allow. Pressure Increase per foot of width when footing is wider than	=	0.0 ksf
	=	0.0 ft


Adjusted Allowable Bearing Pressure

= 4.0 ksf

Dimensions


Reinforcing

Footing Width	=	3.0 ft	Footing Thickness	=	16.0 in	Bars along X-X Axis	=	
Wall Thickness	=	12.0 in	Rebar Centerline to Edge of Concrete... at Bottom of footing	=	3.0 in	Bar spacing	=	12.00
Wall center offset from center of footing	=	3 in				Reinforcing Bar Size	=	# 6



Applied Loads

	D	Lr	L	S	W	E	H
P : Column Load	=	3.570	0.0	0.0	0.8850	0.0	0.6650 k
OB : Overburden	=	0.0	0.0	0.0	0.0	0.0	0.0 ksf
V-x	=	0.0	0.0	0.0	0.0	0.0	0.0 k
M-zz	=	0.0	0.0	0.0	0.0	0.0	0.0 k-ft
Vx applied	=	0.0 in above top of footing					



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 22 AUG 2016. 3:05PM

Wall Footing

Projects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build.6.16.6.7, Ver.6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Continuous Wall Footing

DESIGN SUMMARY

Design OK

Factor of Safety	Item	Applied	Capacity	Governing Load Combination	
PASS	n/a	Overturning - Z-Z	0.0 k-ft	0.0 k-ft	No Overturning
PASS	n/a	Sliding - X-X	0.0 k	0.0 k	No Sliding
PASS	n/a	Uplift	0.0 k	0.0 k	No Uplift

Utilization Ratio	Item	Applied	Capacity	Governing Load Combination	
PASS	0.6855	Soil Bearing	2.742 ksf	4.0 ksf	+D+S+H
PASS	0.03827	Z Flexure (+X)	0.9634 k-ft	25.171 k-ft	+1.20D+0.50L+1.60S+1
PASS	0.03060	Z Flexure (-X)	0.7701 k-ft	25.171 k-ft	+0.90D+E+0.90H
PASS	n/a	1-way Shear (+X)	0.0 psi	100.623 psi	n/a
PASS	0.02535	1-way Shear (-X)	2.550 psi	100.623 psi	+1.20D+0.50L+1.60S+1

Detailed Results

Soil Bearing

Rotation Axis & Load Combination...	Gross Allowable	Xecc	Actual Soil Bearing Stress		Actual / Allowable Ratio
			-X	+X	
. +D+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+L+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+Lr+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+S+H	4.0 ksf	2.695 in	1.058 ksf	2.742 ksf	0.686
. +D+0.750Lr+0.750L+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+0.750L+0.750S+H	4.0 ksf	2.682 in	1.021 ksf	2.632 ksf	0.658
. +D+0.60W+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+0.70E+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+0.750Lr+0.750L+0.450W+H	4.0 ksf	2.639 in	0.9086 ksf	2.301 ksf	0.575
. +D+0.750L+0.750S+0.450W+H	4.0 ksf	2.682 in	1.021 ksf	2.632 ksf	0.658
. +D+0.750L+0.750S+0.5250E+H	4.0 ksf	2.682 in	1.021 ksf	2.632 ksf	0.658
. +0.60D+0.60W+0.60H	4.0 ksf	2.639 in	0.5451 ksf	1.381 ksf	0.345
. +0.60D+0.70E+0.60H	4.0 ksf	2.639 in	0.5451 ksf	1.381 ksf	0.345

Overturning Stability

Units : k-ft

Rotation Axis & Load Combination...	Overturning Moment	Resisting Moment	Stability Ratio	Status
-------------------------------------	--------------------	------------------	-----------------	--------

Footing Has NO Overturning

Sliding Stability

Force Application Axis Load Combination...	Sliding Force	Resisting Force	Sliding Safety Ratio	Status
--	---------------	-----------------	----------------------	--------

Footing Has NO Sliding

Footing Flexure

Flexure Axis & Load Combination	Mu k-ft	Which Side ?	Tension @ Bot. or Top ?	As Req'd in^2	Gvrn. As in^2	Actual As in^2	Phi*Mn k-ft	Status
. +1.40D+1.60H	1.22	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.40D+1.60H	0.881	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50Lr+1.60L+1.60H	1.071	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50Lr+1.60L+1.60H	0.7753	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60L+0.50S+1.60H	1.145	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60L+0.50S+1.60H	0.8341	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60Lr+0.50L+1.60H	1.071	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60Lr+0.50L+1.60H	0.7753	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60Lr+0.50W+1.60H	1.071	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60Lr+0.50W+1.60H	0.7753	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50L+1.60S+1.60H	1.307	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50L+1.60S+1.60H	0.9634	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60S+0.50W+1.60H	1.307	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+1.60S+0.50W+1.60H	0.9634	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50Lr+0.50L+W+1.60H	1.071	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50Lr+0.50L+W+1.60H	0.7753	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50L+0.50S+W+1.60H	1.145	-X	Bottom	0.3456	Min Temp %	0.44	25.171	OK
. +1.20D+0.50L+0.50S+W+1.60H	0.8341	+X	Bottom	0.3456	Min Temp %	0.44	25.171	OK

USGS Design Maps Summary Report

User-Specified Input


Report Title Liberty Upper System Tank
Wed August 17, 2016 16:17:16 UTC

Building Code Reference Document ASCE 7-10 Standard
(which utilizes USGS hazard data available in 2008)

Site Coordinates 41.3864°N, 111.9022°W

Site Soil Classification Site Class B – "Rock"

Risk Category I/II/III




USGS-Provided Output


$S_S = 1.068 \text{ g}$	$S_{MS} = 1.068 \text{ g}$	$S_{DS} = 0.712 \text{ g}$
$S_1 = 0.370 \text{ g}$	$S_{M1} = 0.370 \text{ g}$	$S_{D1} = 0.247 \text{ g}$

For information on how the S_S and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the "2009 NEHRP" building code reference document.

MCE_R Response Spectrum



Design Response Spectrum




For PGA_M , T_L , C_{RS} , and C_{R1} values, please [view the detailed report](#).

Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TAB



D _{tank}	53	ft
H _L	16	ft
g	32.17	ft/s ²
λ	9.758527418	
T _C	4.687416198	s
S _{D1}	0.247	g
S _{DS}	0.712	g
T _S	0.346910112	s
C _C	0.077772167	
I	1.25	
d _{max}	2.576203046	ft

Required Freeboard


Tank Volume	255802	Gallons
Ht to Water	15.5	ft

New H _L	15.5	ft
New d _r	0.5	ft

Height to Liquid after Freeboard Check (IF desired to change from above)

h _n	17	ft
T	0.167442881	s
T _o	0.069382022	s
T _L	8	s
S _a	0.456457993	g
S _a	0.712	g


height above base to highest level of structure
 Approximate Fundamental Period as Per ASCE 7 eqn 12.8-7
 Per ASCE 7
 Per ASCE 7 (fig 22-15)
 For periods less than T_o
 For periods >= to T_o and <= to T_s



Find Pressure at Roof to Shell interface from insufficient freeboard depth.

SA (T _c)	0.052694275	g	Spectral Acceleration at T _c
Theta	3.01636981	degrees	Angle of free surface at sloshing load
h _r	0.5	ft	height from top of wall to underside of topmost point of lid
V _{EMPTY}	1470.788961	ft ³	Empty Volume of tank above water
d	1.396398298	ft	Vertical displacement of liquid surface
d _f /d	0.358064029		
h _r /d	0.358064029		
X _f /R	0.95		Fig 6 from "Earthquake Induced Sloshing in Tanks with insufficient Freeboard"
X _f	25.175	ft	
ρ	1.94	slugs/ft ³	mass density of liquid
P _{max}	32.21	psf	Weight of Roof is heavier, therefore ok
F _{max}	405.48	plf	#5 Radial Dowels @ 16" o.c. okay (Roof Slab to Wall)

Slab wt = 150 pcf, 8" / 2 . 0.6 = 60 psf
 $P_r / w_c = \frac{60 \text{ ksl} \cdot 0.31 \text{ m}^2 \cdot 12'' / 16''}{1.67} = 8353 \text{ plf}$



Weight

D/H _L	3.419354839			
W _i /W _L	0.33	PCA EB219 fig 4-4 (b)		
W _c /W _L	0.61	PCA EB219 fig 4-4 (b)		
W _L	2223 kips	Weight Of Water		
W _i	734 kips	Impulsive Weight		
W _c	1356 kips	Convective Weight		
Tw	12 inches	Wall Thickness	D _{outer}	55.00 ft
Tr	8 inches	Roof Thickness		
W _w	407 kips	Weight of Walls		
W _R	238 kips	Weight of Roof		

Period

Cw	0.142	PCA EB219 fig 4-10		
C _L	0.28			
E _c	3605 ksi	Elastic Modulus of Concrete		
ρ _c	4.66 #-s/ft ³	Mass Density of Concrete		
ω _l	187.8341836 rad/s			
T _l	0.03 s			

Base Shear

R	1.5	Response Modification Factor		
C _{si}	0.59			
C _{si (min)}	6.15			
C _{sc}	0.59			
C _{sc (min)}	0.04			
V _i	1022 kips	Impulsive Base Shear		
V _c	74 kips	Convective Base Shear		
V _T	1025 kips	Total Base Shear		

Overturning Moment

h_i/H_L	0.375	PCA EB219 fig 4-5 (b)	
h_c/H_L	0.54	PCA EB219 fig 4-5 (b)	
h_i	5.8125	ft	
h_c	8.37	ft	
h_w	8	ft	
M_i	6718	kip ft	Impulsive
M_c	6733	kip ft	Convective (Per ACI 350)
M_T	9511	kip ft	Total

Overall Stability Check

Sliding (Neglecting Backfill)

Weight of tank w/out contents:

Walls	407	kips
Roof	238	kips
Columns	30	kips
Base Slab	229	kips
Water	2223	kips
Total Weight	3127	kips
Friction Coeff	0.41	
Base Shear	1025	
Safety Factor	1.25	ok

Overturning

OTM	9511	kip ft
RM	82856	kip ft
Safety Factor	8.7	ok

Design of Walls for In-Plane Loading


V_u	1025	kips	Base Shear
V_c	9.8	kips/ft	Shear in wall
α_c	3	See ACI 318 eqn 21-7	
ρ_t	0.006111	See ACI 318 eqn 21-7	
ϕV_n	60.1	kips/ft	ok

#6 at 12" oc EF
 $\phi V_n = 60.1 \text{ K/ft} \Rightarrow V_c = 9.8 \text{ K/ft} \therefore \text{OK}$


PER PCA EB219 for $D \gg H$ out of plane bending effects are small and can be neglected.

Seismic Forces on Empty Tank

$$\text{seismic Active Pressure} = 46 \text{ pcf} \cdot 16' = 736 \text{ psf}$$



=



$$\text{At-Rest Pressure} = 57 \text{ pcf} \cdot 16' = 912 \text{ psf}$$

W =

$$M_{\max} = 1.649 \text{ K-ft} @ 7.863'$$

* SEE EMERCALC SOLUTION


* Equivalent W

$$1.649 \text{ K-ft} = \frac{w(16)}{2} \cdot \frac{7.863' (16^2 - 7.863^2)}{3 \cdot 16^2}$$

$$W = 104 \text{ pcf}$$

↑

This is used in spreadsheet



ARW Engineers
1594 W Park Circle
Ogden, UT 84404

Project Title:
Engineer:
Project Descr:

Project ID:

Printed: 23 AUG 2016, 8:32AM

Steel Beam

jects 2016\16194 - LPC - Upper System Tank\Engineering\Calculations\Other\16194_lpc - upper system tank.ec6
ENERCALC, INC. 1983-2016, Build:6.16.6.7, Ver:6.16.6.7

Lic. #: KW-06002489

Licensee: ARW ENGINEERS

Description: Maximum Moment

CODE REFERENCES

Calculations per AISC 360-10, IBC 2012, ASCE 7-10

Load Combination Set: ASCE 7-10

Material Properties


Analysis Method: Allowable Strength Design

Fy: Steel Yield: 50.0 ksi

Beam Bracing: Beam is Fully Braced against lateral-torsional buckling

E: Modulus: 29,000.0 ksi

Bending Axis: Major Axis Bending



Applied Loads

Service loads entered. Load Factors will be applied for calculations.

Beam self weight NOT internally calculated and added

Load for Span Number 1

Varying Uniform Load: D(S,E) = 0.0570->0.0 k/ft, Extent = 0.0 --> 16.0 ft, Trib Width = 1.0 ft

Varying Uniform Load: D(S,E) = 0.0->0.0460 k/ft, Extent = 0.0 --> 16.0 ft, Trib Width = 1.0 ft

DESIGN SUMMARY

				Design OK			
Maximum Bending Stress Ratio =	0.039 : 1	Maximum Shear Stress Ratio =	0.011 : 1				
Section used for this span	W8x18	Section used for this span	W8x18				
Ma : Applied	1.649 k-ft	Va : Applied	0.4267 k				
Mn / Omega : Allowable	42.415 k-ft	Vn/Omega : Allowable	37.444 k				
Load Combination	+D+H	Load Combination	+D+H				
Location of maximum on span	7.863ft	Location of maximum on span	0.000 ft				
Span # where maximum occurs	Span # 1	Span # where maximum occurs	Span # 1				
Maximum Deflection							
Max Downward Transient Deflection	0.000 in	Ratio =	0 < 360				
Max Upward Transient Deflection	0.000 in	Ratio =	0 < 360				
Max Downward Total Deflection	0.042 in	Ratio =	4518 >= 180				
Max Upward Total Deflection	0.000 in	Ratio =	0 < 180				

Maximum Forces & Stresses for Load Combinations

Load Combination	Segment Length	Span #	Max Stress Ratios		Summary of Moment Values						Summary of Shear Values			
			M	V	Mmax +	Mmax -	Ma Max	Mnx	Mnx/Omega	Cb	Rm	Va Max	Vnx	Vnx/Omega
+D+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+L+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+Lr+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+S+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.750Lr+0.750L+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.750L+0.750S+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.60W+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.70E+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.750Lr+0.750L+0.450W+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.750L+0.750S+0.450W+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+D+0.750L+0.750S+0.5250E+H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44
+0.60D+0.60W+0.60H	Dsgn. L = 16.00 ft	1	0.039	0.011	1.65		1.65	70.83	42.42	1.00	1.00	0.43	56.17	37.44

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised 10/20/2010
 Reviewed By: TAB



Circular Concrete Tanks without Prestressing
 (Based on the 1993 PCA Document)

Design Criteria

f'c	4500	psi
D _{tank}	53	ft
H _{tank}	16	ft
t _{wall}	12	in
Fluid Pressure	62.4	pcf
Soil Pressure	104	pcf
E _s	29000000	psi
E _c	3823676.24	psi
n	7.6	
Surcharge	175	pcf
Soil on Lid	1	ft
Load Factor		
F _{liquid pressure}	1.4	
F _{soil pressure}	1.6	
Environmental Durability Factor		
Flexure (liquid)	1.93	
Tension (liquid)	1.93	
Flexure (soil)	1.69	
Compression (soil)	1	
H ² /Dt	4.83	

Estimation of Tank Wall Thickness

Limit Ring Tension Stress in Concrete Wall from 7% to 12% of f'c

For given t and H²/Dt, with a hinged base/free top (Table A-5)

Max Coefficient= 0.611 (Table A-5)

W_u 169 pcf

T_{max} 43647 lbs.

T_{unfactored} 16154 lbs.

A_{s(req'd)} 0.81 in²

A_{s(used)} 0.88 in²

OK

F_{t(conc)} 158 psi

This equates to 3.51 % of f'c
 Wall thickness is OK

Compression Check	
F'c	684
0.33f'c	1485
OK	

The Following Load Cases were used in Analysis:

- Load Case #1: Full of Water, No Lid, No Backfill
- Load Case #2: Empty, No Lid, w/Backfill
- Load Case #3: Empty, w/Lid, w/Backfill
- Load Case #4: Full of Water, w/Lid, Ignore Backfill

Load Case #1-Full of Water, No Lid, No Backfill

Assume Free Top/Hinged Base (Tables A-5 and A-7)

Effects of Possible outward movement will be handled by designing the entire portion of the wall for the maximum Ring Tension and Moment


Ring Force=(A-5 Coef.)w_uHR = 71488.4352

Moment =(A-7 Coef.)w_uH³ = 690605.2608

	A-5 Coef.	RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.004	-268	0	0
0.1H	0.118	8429	0.0000	12
0.2H	0.238	17018	0.0002	139
0.3H	0.358	25583	0.0008	532
0.4H	0.469	33528	0.0019	1304
0.5H	0.559	39970	0.0038	2618
0.6H	0.611	43647	0.0061	4241
0.7H	0.597	42679	0.0085	5865
0.8H	0.493	35279	0.0098	6773
0.9H	0.288	20556	0.0080	5551
Bottom	0.000	0	0	0

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD



Load Case #2-Empty, No Lid, w/ Backfill

Use Durability Coefficients as Noted Previous

Soil Over Lid= 1 ft
 ρ 175

Ring Force=(A-5 Coef.) w_u HR+(A-6 Coef.) ρ R

w_u HR= -136168
 ρ R= -14320.6

Moment=(A-7 Coef.)($w_u h^3 + \rho h^2$)

$w_u h^3 + \rho h^2$ = -1273000

	A-5 Coef	RF (#)	A-6 Coef.	RF (#)	Total RF (#)	A-7 Coef.	Moment (#-ft/ft)
Top	-0.004	511	0.996	-14266.8302	-13756	0	0
0.1H	0.118	-16055	1.018	-14577.0198	-30632	0.0000	-22
0.2H	0.238	-32416	1.038	-14865.5934	-47281	0.0002	-257
0.3H	0.358	-48730	1.058	-15149.3034	-63880	0.0008	-980
0.4H	0.469	-63863	1.069	-15308.7214	-79172	0.0019	-2404
0.5H	0.559	-76134	1.059	-15167.1366	-91301	0.0038	-4825
0.6H	0.611	-83137	1.011	-14471.6418	-97609	0.0061	-7818
0.7H	0.597	-81293	0.897	-12845.5782	-94138	0.0085	-10811
0.8H	0.493	-67198	0.693	-9931.201	-77129	0.0098	-12485
0.9H	0.288	-39155	0.388	-5549.908	-44705	0.0080	-10232
Bottom	0.000	0	0.000	0	0	0	0

Load Case #3-Empty, w/Lid, w/Backfill

Apply a shear force (V) @ top of wall to make Ring Tension = 0 @ top of Wall

When top of tank is free, Ring Force (LC#2) = -13756 #

At top of wall (0.0H) from table A-8, Coefficient= -8.07 #

Therefore, the shear force (V) required to produce zero ring force at the top of the tank=
 (Coef. A-8 @ 0.0H)(VR/H)=(Ring Force from LC#2)

Therefore

V= -1029 #
 VR/H= -1704 #

Delta_{RF}=Change in Ring Force Due to V applied @ the top of wall

Delta_{RF}=(A-8 Coef.)(VR/H)

Find the change in moment (Delta_{mom}) due to the V applied @ top.


If S_D for moment is less than S_D for compression, then V is reduced by (S_{DM}/S_{DC})

Delta_{mom}=(A-9 Coef.)VH
 VH= -16465

	A-8 Coef.	Delta _{RF} (#)	LC#2 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC #2 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.071	13756	-13756	0	0	0	0	0
0.1H	-4.946	8430	-30632	-22202	0.0647	-1065	-22	-1087
0.2H	-2.475	4219	-47281	-43062	0.0797	-1312	-257	-1569
0.3H	-0.843	1436	-63880	-62443	0.0694	-1142	-980	-2122
0.4H	0.059	-101	-79172	-79272	0.0497	-819	-2404	-3223
0.5H	0.434	-740	-91301	-92041	0.0305	-503	-4825	-5328
0.6H	0.480	-817	-97609	-98426	0.0150	-248	-7818	-8066
0.7H	0.363	-619	-94138	-94757	0.0042	-69	-10811	-10880
0.8H	0.198	-338	-77129	-77467	-0.0027	44	-12485	-12441
0.9H	0.060	-102	-44705	-44807	-0.0075	124	-10232	-10108
Bottom	0.000	0	0	0	-0.0124	203	0	203

Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised: 1/19/2006
 Reviewed By: TMD



Load Case #4-Full of Water, w/Lid, ignore Backfill

Add the effects of shear @ the top of the tank to LC #1

At the top of the wall - Coefficient from Table A-8= -8.07 #

(Coef. A-8 @ 0.0H)(VR/H) = (Ring Force from LC#1)

V= -20 #
 VR/H= -33 # (For Ring Force)
 VH= -321 # (For Moment)


	A-8 Coef.	Delta _{RF} (#)	LC#1 RF (#)	Total RF (#)	A-9 Coef.	Delta _{mom} (#-ft/ft)	LC#1 Moment (#-ft/ft)	Total Moment (#-ft/ft)
Top	-8.07	268	-268	0	0	0	0	0
0.1H	-4.95	164	8429	8593	0.065	-21	12	-9
0.2H	-2.48	82	17018	17101	0.080	-26	139	114
0.3H	-0.84	28	25583	25611	0.069	-22	532	509
0.4H	0.06	-2	33528	33526	0.050	-16	1304	1288
0.5H	0.43	-14	39970	39956	0.031	-10	2618	2608
0.6H	0.48	-16	43647	43631	0.015	-5	4241	4237
0.7H	0.36	-12	42679	42667	0.004	-1	5865	5864
0.8H	0.20	-7	35279	35272	-0.003	1	6773	6774
0.9H	0.06	-2	20556	20554	-0.008	2	5551	5553
Bottom	0	0	0	0	-0.012	4	0	4

Envelope of Ring Forces

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	-268	-13756	0	0	0	-13756
0.1H	8429	-30632	-22202	8593	8593	-30632
0.2H	17018	-47281	-43062	17101	17101	-47281
0.3H	25583	-63880	-62443	25611	25611	-63880
0.4H	33528	-79172	-79272	33526	33528	-79272
0.5H	39970	-91301	-92041	39956	39970	-92041
0.6H	43647	-97609	-98426	43631	43647	-98426
0.7H	42679	-94138	-94757	42667	42679	-94757
0.8H	35279	-77129	-77467	35272	35279	-77467
0.9H	20556	-44705	-44807	20554	20556	-44807
Bottom	0	0	0	0	0	0


	Tension	Compression
Bottom	0	0
0.9H	21	-45
0.8H	35	-77
0.7H	43	-95
0.6H	44	-98
0.5H	40	-92
0.4H	34	-79
0.3H	26	-64
0.2H	17	-47
0.1H	9	-31
Top	0	-14

Controls (handwritten note with arrow pointing to the -98 value in the 0.6H row)



Project Name LPC - Upper System Tank
 Project # 16194
 Prepared By WWY
 Date 8/23/2016

Program Authors: TAB & DOC
 Last Revised 1/19/2006
 Reviewed By: TMD




Envelope of Moments

	LC#1	LC#2	LC#3	LC#4	Max	Min
Top	0	0	0	0	0	0
0.1H	12	-22	-1087	-9	12	-1087
0.2H	139	-257	-1569	114	139	-1569
0.3H	532	-980	-2122	509	532	-2122
0.4H	1304	-2404	-3223	1288	1304	-3223
0.5H	2618	-4825	-5328	2608	2618	-5328
0.6H	4241	-7818	-8066	4237	4241	-8066
0.7H	5865	-10811	-10880	5864	5865	-10880
0.8H	6773	-12485	-12441	6774	6774	-12485
0.9H	5551	-10232	-10108	5553	5553	-10232
Bottom	0	0	203	4	203	0

	Tension O.F.	Tension I.F.
Bottom	0	0
0.9H	6	-10
0.8H	7	-12
0.7H	6	-11
0.6H	4	-8
0.5H	3	-5
0.4H	1	-3
0.3H	1	-2
0.2H	0	-2
0.1H	0	-1
Top	0	0

Controls (handwritten note pointing to the 0.8H row)



Design of Wall SteelRing steel

- Compression

$$f_c = C/A = 98^k / 12 \cdot 12 = 681 \text{ psi}$$

$$c = 98^k @ 0.6H$$

$$1/3 (4500 \text{ psi}) = 1500 \text{ psi} > 681 \text{ psi} \therefore \text{OK}$$

- Tension

$$A_s = 44.0^k / 0.9 \cdot 60 \text{ ksi} = 0.82 \text{ in}^2$$

$$\text{USE \#6 BARS @ 12" o.c. Each Face} = 0.88 \text{ in}^2 > 0.82 \text{ in}^2 \therefore \text{OK}$$

F_x OK (see spreadsheet)

Design of Wall Steel

Moment Reinforcing

- steel at Interior Face

$$m_u = 12 \text{ k-ft}$$

$$\frac{m_u}{\phi f'_c b d^2} = \frac{12 \text{ k-ft} \cdot 12}{0.9 \cdot 4.5 \cdot 12 \cdot 9.5^2} = 0.0328$$

$$w = 0.034 \quad [\text{Table A-20}]$$

$$p = 0.034 \cdot 4.5 / 60 = 0.00255$$

$$p_{\min} (\text{temp. shrinkage}) = 0.003$$

\therefore MW Reinforcement provided is adequate

* $m_u = 7 \text{ k-ft}$ @ Exterior Face \therefore min. steel Reinforcement is adequate