

WEBER COUNTY

DATE May 2, 2018

PRE CONSTRUCTION MINUTES FOR Sun Crest Meadows Sewer

WATER:

SEWER: - we will need approval from Lance about connection to mainline.  
- we will need a trench detail  
+ 6-8" of rock base, possibly more due to groundwater  
+ 4" of oil  
- place laterals @ center of lot unless otherwise requested by resident  
- county will require camera and air test. Manhole should be air tested.  
- compaction testing every 150' @ 1' lifts.

ROADS:

SECONDARY WATER

OTHER UTILITIES:

TIME FRAME:

PERMITS / BONDING / INSURANCE:

OTHER COMMENTS:

WEBER COUNTY

DATE May 2, 2018

PRE CONSTRUCTION MINUTES FOR Sun Crest Meadows Sewer

ATTENDEES

ADDRESS

PHONE

Braden Felix 801-399-8761

JIM FLINT 970-749-4314

Wyatt Smale 801-458-5788

Carson Wilson 801-941-2018

Roger Owens 801 458 5165

Blank lined area for additional attendees and notes.