

## **Weber Fire District**

## **Preliminary Plan Review**

Date: February 4, 2017

**Project Name**: Alpine Engineering and Construction Sketch Plan Endorsement **Project Address: 2665 S 3500 W Taylor Ut** 

Contractor/Contact: E.Hal Christensen <u>ehchristensen@comcast.net</u> 801-458-9647 Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Туре	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Subdivision 18 Lots			\$50.00
<b>Residential Impact Fee</b>	328.15			\$0.00
				\$0.00
				\$0.00
-		- -	Total Due	\$50.00

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: <u>Weber Fire District.</u>

## PRELIMINARY REVIEW STATUS: FEASIBLE

## **SPECIFIC COMMENTS:**

- 1. Fire Hydrant(s): Hydrants must be provided so that the maximum spacing between hydrants in a residential area is 500 ft.
- 2. Fire Flow: Fire flow for the subdivision shall be 1000 GPM.
- 3. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.
- 4. Dead end fire apparatus access roads in excess of 150 feet in length shall be provide with an approved area for turning around fire apparatus constructed with the same requirements as the roads.
- 5. For subdivisions with more than 30 single family residences, a second fire apparatus access road required.
- 6. Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- 7. All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- 8. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
- 9. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.



**Weber Fire District** 

**Preliminary Plan Review** 

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson Fire Marshal

cc: File