



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF DRINKING WATER
Marie E. Owens, P.E.
Director

May 15, 2017

Val Surrage
Taylor West-Weber Water District
2815 West 3000 South
West Haven, Utah 84401

Subject: **Plan Submittal Waiver**, Taylor West-Weber Water District - Winston Park
Subdivision, System #29019, File #10836

Dear Mr. Surrage:

The Division of Drinking Water (the Division) received a Project Notification Form from your office for Winston Park Subdivision with a request for a Plan Submittal Waiver in accordance with *R309-500-6(3)(b)* of the Utah Administrative Code on April 28, 2017. The Division also received a hydraulic modeling analysis certification dated April 24, 2017 by Dan White, P.E., and a certification dated April 24, 2017 by Dan White, P.E., stating that Plan Submittal Waiver conditions will be met prior to placing the new water lines in service for this project.

Our understanding of the project is that 3,450 linear feet of 10-inch and 950 feet of 8-inch C900 DR14 PVC water lines, nine (9) fire hydrants, and associated valves will be constructed on the south side of 1800 south, between approximately 3600 south and 3700 south in wester Weber County. This project will add 54 new service connections to the water system.

Your water system has formally designated Dan White, P.E., as the Professional Engineer having direct responsibility for the entire water system in your letter to the Division dated August 23, 2012; and Dan White, P.E., as the Professional Engineer responsible for oversight of the hydraulic analysis for the entire water system in your letter to the Division dated August 23, 2012. The construction of the proposed water line project shall conform to the construction standards previously approved by the Division on September 10, 2012. The pipeline size is within the limits of Rule *R309-500-6(3)(b)(ii)* based on the population of 7,413 this water system currently serves. On this basis, **a Plan Submittal Waiver is hereby granted for the Winston Park Subdivision water line project**. Please note that approvals or permits by the local authority or county may be necessary before beginning construction of this project.

Val Surrage
Page 2 of 2
May 15, 2017

Upon receiving this Plan Submittal Waiver, you may proceed with construction of the Winston Park Subdivision water line project. Upon completion of construction and the Plan Submittal Waiver conditions certified by Dan White, P.E., you may place the new water lines in service. You are not required to obtain an Operating Permit for this project.

If you have any questions regarding this letter, please contact Kelly Casteel, of this office, at (801) 536-2465.

Sincerely,



Marie E. Owens, P.E.
Director

KDC/nl/dg/hb

cc: Louis Cooper, Environmental Health Director, Weber-Morgan Health Dept, lcooper@co.weber.ut.us
Dan White, Gardner Engineering, dan@gecivil.com
Kelly Casteel, Division of Drinking Water, kcasteel@utah.gov

DDW-2017-004906.docx