

WEBER COUNTY

DATE 5-29-18

PRE CONSTRUCTION MINUTES FOR Cameron Village Cluster Subdivision

WATER:

- Start on South end for both water and sewer
- Get letter of approval of construction for utilities.

SEWER:

- Start on South end for both water and sewer.
- require an air test and video inspection.
- tracer wire required.
- Get letter of approval of construction for utilities

ROADS:

- Still figuring out the deferral for road half-width
- If installing whole width, get easement for undedicated width and length
- Get mix design to Jeds

SECONDARY WATER

- Get letter of approval of construction for utilities.

OTHER UTILITIES:

TIME FRAME:

- Starting now, pipe crew two weeks out.
- August being ideal pave time.

PERMITS / BONDING / INSURANCE:

- SWPPP needed
- Excavation permit needed

OTHER COMMENTS:

- SWPPP needed
- Excavation permit in place.

