



October 22, 2012

Project: *Hidden Valley Yurt*
Re: *Powder Mnt.*

Mr. Jared Anderson:

The provided design for the proposed Hidden Valley Yurt for Powder Mountain has been designed to accommodate the disbursement of all stormwater that will be generated onsite. The amount of runoff produced by the building itself that would require detention is negligible. The stormwater from the building has been designed to discharge to provided riprap to dissipate the small amounts of stormwater from the roof of the building. The generated storm runoff will be disbursed upon the Powder Mountain property.

If you have any questions, or we can be of further assistance, please let us know.

Sincerely,
REEVE & ASSOCIATES, INC.

A handwritten signature in blue ink, appearing to read 'J. Nate Reeve', is written over a horizontal line.

J. Nate Reeve, P.E.
Principal Engineer
nreeve@reeve-assoc.com

Solutions You Can Build On™

Civil Engineering • Land Planning • Structural Engineering • Landscape Architecture • Land Surveying • Construction Surveying
920 Chambers St., Suite 14 • Ogden, Utah 84403 • Tel: 801-621-3100 • Fax: 801-621-2666
ogden@reeve-assoc.com • reeve-assoc.com