



**PERMIT TO CONSTRUCT AN ONSITE WASTEWATER TREATMENT SYSTEM**

**ISSUED BY THE WEBER-MORGAN HEALTH DEPARTMENT**

**477 23rd Street, OGDEN, UTAH 84401**



Permit No. : **W101629**

Issued: **March 28, 2019**

Expires: **March 28, 2020**

This is to certify that **TYLER BELLISTON** is hereby issued a permit to install an onsite wastewater treatment system for the property with the Property Identification Number **21-085-0004** with the following specifications and provisions:

Approximate construction site address: **1330 N MAPLE DR, HUNTSVILLE**

Lot: **100** of the **GREEN HILLS** subdivision in **Weber** county Utah.

Water supply will be provided by: **GREEN HILLS COUNTRY ESTATES.**

Type of System will be **TANK ONLY** with an absorption area of **0** Sq. Ft.

Septic tank capacity must be at least **2500** gallons. System is designed for a **7** bedroom home.

Maximum depth of trench bottoms must be limited to **0** inches from original ground surface.

**\*\*\* IMPORTANT - PLEASE READ CAREFULLY \*\*\***

THREE FOOT MAXIMUM BACKFILL OVER SEPTIC TANK.

INSTALL IN DESIGNATED LOCATION.

INSTALL ACCORDING TO CONSTRUCTION PLANS REVIEWED BY THIS OFFICE.

WATER TIGHTNESS TEST REQUIRED. TANK MUST BE FULL AT TIME OF INSPECTION.

**Please provide the permit number and address when requesting the final inspection or any additional information regarding this system.**

**Final inspection to be completed prior to any backfilling of installed system.**

This permit may be revoked or altered if the site is found to be in a flood hazard or other geologic hazard area. This permit is based on minimum design standards, and in no case does it guarantee against the failure of the installed system. The performance of the installed system is affected by many other factors, such as operation, maintenance, wastewater contents, etc., not addressed by the standards.

*Craig Jorgensen*  
\_\_\_\_\_  
/s/