DESIGN ACCORDING TO THE 2018 IBC FOR SPECIFICATIONS NOT SHOWN REFER TO THE 2018 IBC.

DESIGN CATEGORY:

RISK CATEGORY I - LOW RISK

SEISMIC CRITERIA:

DESIGN CATEGORY D

SOIL SITE CLASS D (ASSUMED)

R = 2.5 (LIGHT-FRAME WALLS WITH SHEAR PANELS OF ALL OTHER MATERIALS)

SS= 0.0g, S1= 0.0g; SDS= 0.0g, SD1= 0.0g ANALYSIS PROCEDURE: EQUIVALENT LATERAL FORCE

BASE SHEAR= 000 LBS

WIND LOAD:

ULTIMATE WIND DESIGN SPEED: 105 MPH 3 SEC. GUST (RISK CATEGORY I, 2018 IBC FIGURE 1609.3(4)) TERRÀIN EXPOSURE C

SNOW LOAD:

SITE ELEVATION: 5090 FT GROUND SNOW LOAD: 43 PSF

ROOF DESIGN SNOW LOAD: 30 PSF

DEAD LOADS:

ROOF STRUCTURE 4 PSF

WALLS 4 PSF

ROOF LIVE LOAD: 20 PSF

FROST DEPTH: 40 IN

CONCRETE FOUNDATION NOTES:


- 1. 28 DAY STRENGTH (F'C) W/ NORMAL 145 PCF DENSITY: FOOTINGS: 3000 PSI
- SLABS ON GRADE: 3000 PSI REQUIRED, 3500 PSI RECOMMEND
- ALL SLABS: PROVIDE A MIN. THICKNESS OF 4" W/ 4" DEEP MIN. CRUSHED GRAVEL BASE.
- CONTRACTION/CONTROL JOINTS SHALL BE INSTALLED IN SLABS ON GRADE SO THE LENGTH TO WIDTH RATIO OF THE SLAB IS NO MORE THAN 1.5:1. CONTROL JOINT SPACING SHALL NOT EXCEED 30 TIMES THE SLAB THICKNESS IN ANY DIRECTION, UNLESS OTHERWISE NOTED.
- CONTROL JOINTS SHALL BE COMPLETED WITHIN 6-18 HOURS OF CONCRETE PLACEMENT.
- CONTROL JOINTS SHALL BE TOOLED OR SAWED TO THE GREATER DEPTH OF 1" DEEP OR 1/4 THICKNESS OF CONCRETE SLAB.

SOILS AND EXCAVATION:

- 7. NO SOILS REPORT PROVIDED STABLE SOIL CHARACTERISTICS ASSUMED. ALL DESIGN WAS BASED ON STABLE SOIL CHARACTERISTICS. GEOTECHNICAL HAZARDS FOUND ON OR AROUND THE SITE, INCLUDING EXPANSIVE CLAYS, OR SOILS FOUND AT THE SITE WHILE EXCAVATION OCCURS WHICH DIFFERS FROM THOSE ASSUMED SHOULD BE BROUGHT TO THE ATTENTION OF THE BUILDING OFFICIAL AND ENGINEER.
- ALLOWABLE BEARING PRESSURE: 1500 PSF NATIVE MATERIAL SURROUNDING FOOTING TO BE
- DISTURBED MINIMALLY DURING EXCAVATION. 10. FOOTINGS SHALL BE PLACED ENTIRELY IN UNDISTURBED NATIVE SOILS OR STRUCTURAL FILL WHICH IS BEARING ON UNDISTURBED NATIVE SOILS AND IS COMPACTED TO 95% OF THE MODIFIED PROCTOR DENSITY.

11. PLEASE REFER TO THE STRUCTURAL CALCULATIONS FOR ALL SPECIFICATIONS AND DESIGN CRITERIA NOT LISTED HERE. WHERE DETAILS ARE NOT SPECIFIED, TYPICAL DETAILS AS SPECIFIED ON PLANS AND ON THE STRUCTURAL DETAILS SHEET SHALL APPLY.

BEEHIVE BUILDINGS MIKE ROUNDY BUILDING



BUILDING INFORMATION

SITE INFORMATION:

ADDRESS: 559 N 5150 E EDEN, UTAH

BUILDING INFORMATION:

DIMENSIONS: 25' x 40' TOTAL SQUARE FOOTAGE: 1400 S.F. MAIN BUILDING: 1000 S.F. LEANS: 400 S.F.

CONTACTS

BEEHIVE BUILDINGS CONTACT: GARRETT NICHOLS

CONTRACTOR:

PHONE: 801-529-4222

DRAFTING AND ENGINEERING:



CONTACT: DEREK LLOYD DEREK@MOUNTAINPOINTENGINEERING.COM

PHONE: 801-450-5332

DRAWING INDEX

SH	IEET	DESCRIPTION	
	00	COVER SHEET	
	01	FOUNDATION PLAN	
	02	FLOOR PLAN	
	03	ROOF PLAN	
	04	GIRT PLAN	
	05	ELEVATIONS	
	06	PANEL LAYOUT	
	07	DETAIL SHEET	[
	38	DETAIL SHEET	
	09	DETAIL SHEET	

PRELIMINARY **NOT FOR PERMIT**

ENGINEER STAMP


01/21/2020

1/8" = 1'-0'

DATE 01/21/2020

SHEET 01

NORTHEAST



NORTHWEST

SOUTHEAST

PIERS:

1. F18: 18" DIA X 40" DEEP CONCRETE PIER
1.1. 24" DIA OK
2. F24: 24" DIA x 40" DEEP CONCRETE PIER

SOUTHWEST

PLAN FLOOR

MIKE ROUNDY BUILDING

EDEN, UTAH


PROJECT B104

SCALE

1/8" = 1'-0'

DATE 01/21/2020

SHEET



SOUTHWEST

NORTHEAST

SOUTHEAST


NOTES:

- 6x6 DF: 6x6 DF-L #2 TREATED POST.
 EMBED POST INTO CONCRETE PIER. SEE DETAIL ON SHEET 8.

 3. ROOF: 29 GA STEEL PANEL

 4. WALLS: STANDARD GIRTS, 29 GA STEEL PANEL

NORTHEAST



NOTES

- TRUSSES WILL BE DEFERRED PER IBC 107.3.4.1
 AND WILL BE DESIGNED BY A LICENSED ENGINEER
 IN THE STATE OF UTAH.
- 2. PROVIDE TRUSS BOTTOM CHORD BRACING PER TRUSS MANUFACTURER'S SPECIFICATIONS.

PROJECT B104

MIKE ROUNDY BUILDING

EDEN, UTAH

SCALE 1/8" = 1'-0"

FRAMING

ROOF

DATE 01/21/2020

SHEET 03

SOUTHWEST



PLAN

GIRT

ENGINEER STAMP

AT 24" (MAX) ON CENTER


AT 24" (MAX) ON CENTER

BY - 0"


BY - 10"

CONTER


AT 24" (MAX) ON CENTER



GABLE END GIRT WALL - NORTHWEST



GABLE END GIRT WALL - SOUTHEAST



SIDE GIRT WALL - SOUTHWEST

SIDE GIRT WALL - NORTHEAST

MIKE ROUNDY BUILDING

EDEN, UTAH

PROJECT B104 SCALE

1/8" = 1'-0"

DATE 01/21/2020

SHEET 04



ENGINEER STAMP


ELEVATIONS

EDEN, UTAH


1/8" = 1'-0" DATE

01/21/2020


SHEET 05




GABLE END ELEVATION - NORTHWEST



GABLE END ELEVATION - SOUTHEAST



SIDE ELEVATION - SOUTHWEST



SIDE ELEVATION - NORTHEAST


ENGINEER STAMP

EDEN, UTAH


1/8" = 1'-0" DATE

01/21/2020


SHEET 06



END PANEL LAYOUT - NORTHWEST





END PANEL LAYOUT - SOUTHEAST



SIDE PANEL LAYOUT - SOUTHWEST

12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	12'-0"	





0,12,1

PIER DETAIL

NOT TO SCALE

MOUNTAIN POINT ENGINEERING

ENGINEER STAMP

ETAIL SHEET

MIKE ROUNDY BUILDING

EDEN, UTAH


PROJECT B104

SCALE AS NOTED

DATE 01/21/2020


> SHEET 08

DOOR JAMB FLASHING NOT TO SCALE




BASE GUARD FLASHING

NOT TO SCALE



WINDOW JAMB FLASHING

NOT TO SCALE



WINDOW / DOOR HEADER FLASHING

NOT TO SCALE

DETAIL SHEET

MOUNTAIN POINT ENGINEERING

MIKE ROUNDY BUILDING
EDEN, UTAH

PROJECT B104

SCALE AS NOTED

DATE 01/21/2020

SHEET 09