

BRIAN W. BENNION, M.P.A., L.E.H.S.
Health Officer/Executive Director



May 13, 2019

Taylor Anderson
3489 West Pioneer Road
Ogden, Utah 84404

RE: Wastewater Site and Soils Evaluation #14818
2230 North 6700 West West Warren, Utah 84404
Parcel # 19-057-0006

An evaluation of the site and soils at the above-referenced address was completed by staff of this office on May 13, 2019. The exploration pit is located on the enclosed plat developed during the site evaluation along with the assigned numerical code for each exploration pit. The soil horizons, required percolation depths, actual and anticipated maximum ground water tables have been logged as follows:

Exploration Pit #2 (UTM Zone 12 Nad 83 404477 E 4572678 N)
0-15" Loam, Granular Structure
15-40" Silty Clay Loam, Blocky Structure
46-62" Silt Loam, Blocky Structure
Observed Groundwater Table 62"
Documented Groundwater Table 12"

Conduct the required percolation test so that the bottom of the percolation test hole is at 27 inches deep from the original grade.

Exploration pits should be backfilled immediately upon completion of percolation testing to prevent a hazardous environment that may cause death or injury to people or animals.

Due to the soil types existing on this property, the final readings of the **percolation tests will need to be witnessed by a representative from the Health Department**. Please make the percolation tester aware of the requirement so that arrangements can be made. Test results will not be accepted if this requirement is not met.

Percolation tests may be completed by any individual on the enclosed list. The stabilized percolation test results are to be submitted to this office for review prior to the recommendation for further development to the appropriate planning agency or prior to the issuance of a wastewater disposal permit.

Monitoring of the maximum ground water table is required in the location of the above listed exploration pits. Please complete the enclosed application for maximum ground water table monitoring and return it along with the appropriate fees. The wells should be constructed in accordance with the enclosed diagram in order to provide the most accurate water table readings possible.

If you have any further questions, contact this office at your convenience.

Sincerely,

Ryan Klinge
Environmental Health Division
801-399-7160

EDUCATE | ENGAGE | EMPOWER

phone: 801-399-7100 | fax: 801-399-7110 | 477 23rd Street, Ogden, UT 84401 | www.webermorganhealth.org