


BRIAN W. BENNION, M.P.A., L.E.H.S.
Health Officer/Executive Director



July 15, 2020

Weber County Planning Commission
2380 Washington Blvd.
Ogden, UT 84401

RE: Preliminary Subdivision **Determination**
Clawson Subdivision, 1 Lot
Parcel #22-015-0006
Soil log #14883

Gentlemen:

The soil and percolation information for the above-referenced lot have been reviewed. Culinary water will be provided by a private well. **The placement of the well is critical so as to provide the required 100 foot protection zone.** The well will need to be dug, tested and the water supply approved prior to issuance of a wastewater disposal permit.

DESIGN REQUIREMENTS

Documented ground water tables not to exceeding 24 inches, fall within the range of acceptability for the utilization of an At-Grade absorption area, as a means of wastewater disposal. Maximum absorption area depth is limited to 0 inches. As defined in the Utah Administrative Code R317-4 Table 6 the absorption area is to be designed using a maximum loading rate of 0.5 gal/sq. ft./day as required for the loam, granular structure soil horizon.

Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.

The following items are required for a formal **subdivision review**; application, receipt of the appropriate fee, and a full sized copy of the subdivision plats showing the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. A subdivision review will not occur until all items are submitted. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time, the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,

Summer Day, LEHS III, Program Manager
Environmental Health Division
801-399-7160