KEYED NOTES ⓚ

1. #10 WIRE IN 3/4" CONDUIT TO NEW 277V 20A 1P BREAKER IN EXISTING 277V PANEL L OR ML. RUN OUTDOOR LIGHT CIRCUIT THROUGH SQUARE D CLASS 8903 TYPE LG40 NEMA 1 CONTACTOR ADJACENT TO PANEL. CONTROL THE CONTACTOR BY PHOTOCELL "ON" AND TIME CLOCK "OFF". USE TORK DGLC100A-NC TIME CLOCK ADJACENT TO CONTACTOR. LOCATE TORK EPC-A PHOTOCELL OUTSIDE OF BUILDING AWAY FROM ANY LIGHT SOURCE OR DIRECT SUNLIGHT. INSTALL MANUAL OVERRIDE TOGGLE 8HR TIME SWITCH ADJACENT TO CONTACTOR. TIME CLOCK MUST RETAIN TIME AND PROGRAM SETTINGS ON LOSS OF POWER FOR AT LEAST 10 HOURS.
2. #10 WIRE IN 3/4" CONDUIT.
3. #12 WIRE IN 3/4" CONDUIT.

LIGHT FIXTURE SCHEDULE

TYPE	MANUFACTURER/CATALOG NO.	MOUNTING	LAMPS
T1	LITHONIA DSX2 LED P4 40K T4M MVOLT HS CBA 30FT. STRAIGHT ALUMINUM POLE GOOD FOR 100MPH WINDS PLUS GUSTS	POLE, POLE BASE	LED (270W)



T1 POLE BASE DETAIL

NO SCALE



No.	Revisions/Issue	Date

Seal

LICENSED PROFESSIONAL ENGINEER
No. 178785
DAVID M. BEAZER
8.18.2020
STATE OF UTAH

Project Title

RV & Boat Storage

Gary Hunt, Architect PC
Architecture / Planning
4058 Harrison Blvd., Suite 310 - Ogden, Utah 84403
Phone: (801) 782-0555
Mobile: (801) 725-1922
Fax: (801) 782-0291
e-mail: garyh@gharchitect.com

Sheet Title

Electrical Plan

Project No.	Date
#2019-19	-
	Scale: 1"=30'-0"

Sheet No.

E1.1