

WEBER-MORGAN H

GARY M. HOUSE, M.P.H. Health Officer / Director

October 29, 2012

Division Directors KAY LARRISON, Administration CLAUDIA PRICE, Nursing & Health Promotion LOUIS COOPER, Environmental Health COLLEEN JENSON, WIC

Kevin Murray 638 E. 1700 N. North Ogden, UT 84414

RE:

Wastewater Site and Soils Evaluation #13889 1639 S. 7500., West Warren

Parcel#

Dear Mr. Murray:

An evaluation of the site and soils at the above-referenced address was completed by staff of this office on October 29, 2012. The exploration pit (s) is located at the referenced GPS coordinate and datum. The soil horizons, required percolation depths, actual and anticipated maximum ground water tables have been logged as follows:

Exploration Pit #1 (UTM Zone 12 Nad 83 (12T) 402428 E 4566014 N) 0–12" loam. massive structure (organica)

sandy clay loam, massive structure 12-34" 34-47" silty clay loam, massive structure loamy sand, massive structure 47-54" 54-63" silty loam, massive structure 63-69" loamy sand, massive structure 69-79" silty loam, massive structure

Exploration pits should be backfilled immediately upon completion of percolation testing to prevent a hazardous environment that may cause death or injury to people or animals.

Conduct the percolation tests so that the bottom of the percolation test holes are at 24 inches deep and 40 inches deep from the original grade.

Percolation tests may be completed by any individual included on the enclosed list. The stabilized percolation test results are to be submitted to this office for review prior to the recommendation for further development to the appropriate planning agency or prior to the issuance of a wastewater disposal permit.

If you have any further questions, contact this office at your convenience.

Sincerely,

Summer Day, LEHS

Environmental Health Division

hmm

SD/jc

WEST WARREN-WARREN WATER IMPROVEMENT DISTRICT 5783 WEST 950 NORTH WARREN, UTAH 84404 801-731-1702

April 11, 2013

On Behalf of Kevin Murray

To Whom It May Concern:

The Board of Directors of the West Warren-Warren Water Improvement District have approved a culinary water connection for the approximate address of 1660 South 7500 West, in West Warren, Utah.

The water is available upon request and payment of all current impact and connection fees assessed by the water district. Current connection and impact fees total \$3,700.00 and are due and payable to the water district upon installation of the water service.

Should you have questions or comments, please contact the district clerk at 801-731-1702.

Sincerely,

Connie S. Judkins District Clerk

RG/csj