

WEBER-MORGAN HEALTH DEPARTMENT

GARY M. HOUSE, M.P.H. Health Officer / Director

November 7, 2012

Division Directors
KAY LARRISON, Administration
CLAUDIA PRICE, Nursing & Health Promotion
LOUIS COOPER, Environmental Health
COLLEEN JENSON, WIC

Weber County Planning Commission 2380 Washington Blvd. Ogden, UT 84401

RE:

Kevin Murray Property, 1 Lot 1639 S. 7500 W., West Warren Parcel#

Gentlemen:

The plans and supporting information for the above-referenced subdivision have been reviewed.

Culinary water will be provided by the West Warren-Warren Water District, an extension of an existing approved community water system. A letter from the water supplier is required.

Soil characteristics, percolation rates of 53 MPI, and anticipated ground water tables not to exceed 24 inches, fall within the range of acceptability for the installation of an At-Grade Wastewater Disposal System. Maximum trench depth is limited to 0 inches. The system is to be installed in the location of the exploration pit.

Plans for the construction of any wastewater disposal system is to be prepared by a Utah State Certified individual and submitted to this office for review prior to issuance of a wastewater disposal permit.

All subdivision plats submitted for review are to show the location of exploration pits and percolation tests. Key number or letter designation will be provided by this office along with logs of soil horizons and final percolation rates. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with Onsite Wastewater Systems Rule, R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan Health Department policies. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling. Please be advised that the conditions of this letter are valid for a period of 18 months. At that time the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,

Summer Day, LEHS

Environmental Health Division

SD/jc









CAPITAL STOCK \$42,000.00. 2799.7 SHARES \$15.00 EACH

Kevin D. Murray and Melissa A. Murray

registered holdered Two ----

Warren Irrigation Company

Thanes

hvanssenable only on the books of the Corporation by the holder hereof in herson or by Ahorney whon surrender of

In Witness Wherent, the said Corporation has caused this Certificate to be signed by its duby authorized sifficers and its Corporate Seal to be hereunto affixed

Speak

Secretary //

Market theywork

President