

Staff Report for Administrative Subdivision Approval

Weber County Planning Division

Synopsis

Application Information

Application Request: Request for final approval of Summerset Farms Subdivision Phase 4, consisting of 3 lots.

Agenda Date: Wednesday, February 17, 2021

Applicant:Bob Favero, ownerFile Number:LVS07302020

Property Information

Approximate Address: 2267 S 3500 W, Ogden, UT, 84401

Project Area: 4.838 acres

Zoning: Agricultural (A-1) Zone
Existing Land Use: Agriculture/Residential

Proposed Land Use: Residential

Parcel ID: 15-078-0046, 15-078-0163, 15-078-0164, 15-078-0040

Township, Range, Section: T6N, R2W, Section 28 SE

Adjacent Land Use

North: Residential/Agricultural South: Agricultural East: 3500 West St West: Residential

Staff Information

Report Presenter: Tammy Aydelotte

taydelotte@webercountyutah.gov

801-399-8794

Report Reviewer: RG

Applicable Ordinances

- Weber County Land Use Code Title 101 (General Provisions) Section 7
- Weber County Land Use Code Title 104 (Zones) Chapter 5 (A-1 Zone)
- Weber County Land Use Code Title 106 (Subdivisions)
- Weber County Land Use Code Title 108 (Standards) Chapter 7 (Supplementary and Qualifying Regulations)

Background

The applicant is requesting approval of Summerset Farms Phase 4 Subdivision consisting of three lots, located at approximately 2267 S 3500 W, Ogden, UT, 84401, in the A-1 Zone. The proposed 4.838 acre lot within this subdivision meets the lot area and lot width requirements of this zone, of 40,000 square feet in area and 150 feet in width. Access for the lot will be from 3500 West St. The purpose of this subdivision is to further separate agricultural lands from a new lot.

Culinary water service will provided by Taylor West Weber Water. Sewer services will be provided by Central Weber Sewer. All review agency requirements must be addressed and completed prior to this subdivision being recorded.

Analysis

<u>General Plan</u>: The proposal conforms to the Western Weber General Plan by creating large lots to maintain the country feel with land that has agricultural and livestock related uses.

<u>Zoning</u>: The subject property is located in an Agricultural Zone A-1 zone. The land use requirements for this zone are stated in the LUC§ 104-5 as follows:

- 1. Designate low-intensity farm areas, which are anticipated to develop in a rural residential development pattern;
- 2. Set up guidelines to continue agricultural pursuits, including the keeping of farm animals; and
- Direct orderly low-density residential development in a continuing rural environment."

[&]quot;The purpose of the A-1 Zone is to:

<u>Small Subdivision</u>: As part of the subdivision process, the proposal has been reviewed against the current subdivision ordinance in LUC 106 chapter 1, and the standards in A-1 zone (LUC 104-5). The proposed subdivision will not create any new public streets. The proposal meets the criteria for a "Small Subdivisions", as defined in LUC 101-7, and can be administratively approved per LUC 106-1-5(b)(1).

Lot area, frontage/width and yard regulations: In the LUC §104-5-7, the A-1 zone requires a minimum lot area of 40,000 square feet and a minimum lot width of 150′. The proposed subdivision is a one lot subdivision that fronts a county road identified as 3500 West Street. Lot 400, is a flag lot, consisting of 3.185 acres, meeting the minimum of 3.00 acre requirement, exclusive of the exclusive access strip. Per 108-7-30, no access strip may exceed 800′ in length. The flag lot access strip shall have a minimum width of 20 feet and a maximum width of 30 feet. No flag lot shall be allowed which proposes to re-subdivide or include within it (including the access strip) any portion of an existing lot in a recorded subdivision. No subdivision shall be vacated, re-subdivided, or changed in order to meet the requirements of this section.

<u>Culinary water and sanitary sewage disposal:</u> A letter from Taylor West Weber Water Improvement District has been provided granting final approval. Secondary Water will be required from Hooper Irrigation. Sanitary sewage disposal will be handled by Central Weber Sewer.

<u>Review Agencies</u>: The proposed subdivision has been reviewed, but not yet approved by Engineering, County Surveyor, and Weber Fire District. *Tax Clearance*: There are no outstanding tax payments related to this parcel.

<u>Public Notice</u>: Noticing requirements, according to LUC 106-1-6(c), have been met by mailing notices out to all property owners of record within 500 feet of the subject property.

Conformance to the General Plan

Subdivisions that meet the requirements of applicable County Ordinances conform to the General Plan. This subdivision addresses water, wastewater, pathways, and other issues which are discussed in the General Plan.

Staff Recommendations

Staff recommends final approval of Summerset Farms Phase 4 Subdivision, consisting of three lots. This recommendation is subject to all review agency requirements and based on the following conditions:

- 1. An updated title report will need to be submitted prior to recording this subdivision.
- 2. A pathway easement, that shows connection to a future pathway in Phase 3, must be shown on the final plat.
- 3. A signed deferral agreement for curb, gutter, and sidewalk, must be recorded with the final plat.
- 4. A signed deferral agreement for the pathway, must be recorded with the final plat.

This recommendation is based on the following findings:

- The proposed subdivision conforms to the Western Weber General Plan.
- 2. With the recommended conditions, the proposed subdivision complies with applicable county ordinances.

Administrative Approval

Administrative final approval of Summerset Farms Subdivision Phase 4 is hereby granted based upon its compliance with the Weber County Land Use Code. This approval is subject to the requirements of applicable review agencies and the conditions of approval listed in this staff report.

Date of Administrative Approval: Wednesday, February 24, 2021.

Rick Grover

Weber County Planning Director

Exhibits


- A. Application
- B. Subdivision Plat
- C. Water/Septic Feasibility



Exhibit A - Application

Weber County Subdivision Application All subdivisions submittals will be accepted by appointment only. (\$802) 399-8791. 2380 Washington Blvd. Suite 240, Opden, UY 84401				
				Date Submitted / Completed
Subdivision and Property	Information	I-MAJIA	reviewed their own side value fine	
Subdivision Name Summerse	A FARME P	hase 4 LandSorialNumber(s)	Number of Loss	
Jacob Su	3500W	LandSerialAumber(s)	-0046	
Eurrant Zoning	Total Acreage	}		
Culingy Water Provider Taylor West	Weby Hoo		ebercentralsone	
Property Owner Contact I	information			
Name of Property Owner's) Robert FAVIV Property Fax		2049 BIL	8049 Bluff Ridge Dr. Supracuse, W184075	
801 644 3701 Email Address	6	Preferred Method of Written Corn	Medandence	
vobert/fave	urc @ hotmail.co	mei Fax Mi	ji	
Authorized Representative	e Contact Information			
Name of Person Authorized to Bept Robert H	resent the Property Owner(s)	Mailing Address of Authorized Per	sen	
201 644 3700	6			
ropotifay	ergohetmuil.	Professed Method of Written Corri		
Surveyor/Engineer Contac	t Information			
Name or Company of Surveyor/Eng Errent Bus M Phone	Engrecorne	Mailing Address of Surveyor/Engin	eer	
Email Address		Preferred Method of Written Corre Email Fai Mis		
Property Owner Affidavit				
and that the statements herein co	intained, the Information provided owledge that during the subclivision constructed or entered into.	P COM	all respects true and correct to the best of	

Exhibit B - Proposed Plat



TAYLOR WEST WEBER WATER IMPROVEMENT DISTRICT

2815 WEST 3300 SOUTH WEST HAVEN, UTAH 84401 May 29, 2020

Weber County Planning Commission 2380 Washington Boulevard Ogden, Utah 84401

To Whom It May Concern:

This is to inform you that <u>Final</u> approval of the Summerset Farms subdivision is accepted by Taylor West Weber Water. The water lines have been installed and tested. The water services have been completed to a point that building permits may be issued. Blow off assemblies have also been completed to a point that building permits may be issued. Before meters are set the proper lids must be installed and the blow off assemblies must be completed to Taylor Weber Water Standards. The valves boxes must be raised and collared after asphalt is installed as well. **BEFORE ALL ESCROW FUNDS ARE RELEASED TAYLOR WEST WEBER WATER WILL DO A FINAL INSPECTION** and verify all items meet the district standards.

Sincerely,

TAYLOR WEST WEBER WATER IMP. DISTRICT Ryan Rogers – Manager