


REL NO	LTR	NO	REVISION	DWN	CKD	APVD	DATE
ECO-178681	E	1	ZONE A4; F231-2 AND F216-2... CONFIGURATIONS WAS F231-2...				
			CONFIGURATION	PPP	KAM	WINGFIELD	09 JUL 18
		2	UPDATE VIEWS PICTORIALLY	PPP	KAM	WINGFIELD	09 JUL 18


NOTES:

- DIM [] IN INCHES
- 120° AND 170° ARE DETENTED OPEN ANGLE FOR HINGE.
- WHEN THE HOUSING INSTALLED ON AN OPEN GENERATOR SET, THE TOTAL WEIGHT WILL INCREASE BY 98 KG (216 LBS). THIS INCLUDES THE MUFFLER.
- THE CENTER OF GRAVITY (CG) OF THE GENERATOR SET WHEN EQUIPPED WITH THIS HOUSING SHIFTS APPROXIMATELY 8MM (0.31 INCH) TOWARDS THE AIR DISCHARGE END OF THE HOUSING AND 38MM (1.5 INCH) HIGHER FROM THE GROUND. COMPARED TO THE EQUIVALENT NON-HOUSED PRODUCT WITH THE F179 SKID. SEE HOUSING READY SKID BASE OUTLINE DRAWING FOR CG LOCATION OF NON HOUSED PRODUCT.




TOP VIEW


DISTANCE REQUIRED TO LIFT OFF SERVICE PANELS




OUTLET VIEW



LEFT SIDE VIEW



INLET VIEW



RIGHT SIDE VIEW

F231-2 AND F216-2 ENCLOSURE CONFIGURATIONS

UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE IN MILLIMETERS		SH TO NONE	DWN S_GAMBHIRE		CUMMINS POWER GENERATION	
DO NOT SCALE PRINT		CKD T_RADKE	OUTLINE, ENCLOSURE			
DIM	X ± 1 .X ± 0.8 .XX ± 0.38	NOTE 0.00- 4.99 +0.15/-0.08 5.00- 9.99 +0.20/-0.10 10.00-17.49 +0.25/-0.13 17.50-24.99 +0.30/-0.13	DATE 17 JAN 13	SITE CODE	PGF	
ANG TOL:	± 0.5°	SCALE: 1/10	ARROW	DWG FILE A043J729	SHEET 1 OF 2	DWG REV E