



CONSTANT RATE PUMP TEST REPORT – WIN: 35658

LEGEND DRILLING SERVICES, LLC.
PO BOX 460
KAMAS, UT 84036
801.557.4404

DATE OF SERVICE: 07.09.20


OWNER NAME: CURTIS HYDE
WATER RIGHTS: E4717 (35-11997)
MAILING ADDRESS:

WELL LOCATION ADDRESS: Parcel: 210370014, Huntsville, UT 84317
WIN: 35658
LEGAL DESCRIPTION: N252 W1375 E4 SEC28 T6N R2E SLBM
GPS: 41.22842602975064, -111.72566402703525

WELL LOG AVAILABLE AT DATE OF SERVICE
KNOWN INFORMATION: DRILLED MAY06, CABLE-TOOL – SUTTON

PUMPING TEST SUMMARY INFORMATION ON 07/09/20:

TYPE OF WELL PUMP: SUBMERSIBLE
DEPTH OF PUMP SETTING: 300' TOC
TYPE OF PUMPING TEST: CONSTANT RATE
METHOD OF WATER LEVEL MEASUREMENT: ELECTRIC SOUNDER, HD CAMERA SURVEY
REFERENCE DATUM FOR WATER LEVEL MEASUREMENTS: TOP OF CASING
METHOD OF FLOW MEASUREMENT: 5-GAL BUCKET (verify flow & sand content evaluation)
DATE OF TEST PUMPING: 07/09/2020
STATIC WATER LEVEL: 34' TOC
DURATION OF PUMPING: 4 HOURS
WELL YIELD ESTIMATED FROM TEST PUMPING: 9-13GPM
DRAWDOWN: 229'
COMMENTS: SURGED/FLUSHED WELL AND TEST PUMPED FOR 4 HOURS. PRESENCE OF IRON OXIDE AND HEAVY SEDIMENT. YIELD: 9-13GPM. 8" WELL-CAP INSTALLED. WELL DISINFECTED UPON COMPLETION.

X 

John Tidwell for Legend Drilling Services, LLC.
Utah Driller's License #920

PLEASE NOTE: The data recorded in this test pumping report reflect conditions at the time of the test. Water levels, well performance, estimated long-term yield and water quality are not guaranteed as they are influenced by a number of factors, including natural variability, human activities, and condition of the works, which may change over time.