



WEBER-MORGAN HEALTH DEPARTMENT

GARY M. HOUSE, M.P.H.
Health Officer / Director

July 10, 2013

Division Directors
KAY LARRISON, Administration
CLAUDIA PRICE, Nursing & Health Promotion
LOUIS COOPER, Environmental Health
COLLEEN JENSON, WIC

Weber County Planning Commission
2380 Washington Blvd.
Ogden, UT 84401

RE: Cole Allen
8106 W 900 S,
Parcel #10-043-0045

Gentlemen:

The plans and supporting information for the above-referenced subdivision have been reviewed.

Culinary water will be provided by the West Warren Water District, an extension of an existing approved community water system. **A Letter from the water supplier is required.**

Soil characteristics, percolation rates of 50 MPI, and ground water table not to exceed 12 inches, fall within the range of acceptability for the installation of a Mound Wastewater Disposal System. The Mound is to be engineered by a designer certified by this office and plans are to be submitted for approval prior to issuance of an individual wastewater disposal permit.

Documentation showing the **Deed Covenant and Restriction** is recorded will be required before a permit will be issued. Mound Wastewater Disposal Systems are required to maintain a bi-annual operating permit issued by the Health Department.


Plans for the construction of any wastewater disposal system is to be prepared by a Utah State Certified individual and submitted to this office for review prior to issuance of a wastewater disposal permit.

All subdivision plats submitted for review are to show the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with Onsite Wastewater Systems Rule, R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan Health Department policies. Final approval will be given only after an on-site inspection of the completed project and documentation of a yearly Operation & Maintenance contract is supplied to the Health Department.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,


Summer Day, LEHS
Environmental Health Division