



2023 West 1300 North  
Farr West Utah, 84404

## PLAN REVIEW

**Date:** January 25, 2022

**Project Name:** Sundown Condos

**Project Address:** 6550 N Powder Mountain Road

**Contractor/Contact:** Jordan Williams

**Fee(s):**

Property Type	Schedule Rates	Rate/1000 Sq Ft	Square Feet or Number of Res. Units	Total
Type	Rate		Sq Ft or # of Units	Total
Plan Review	Residential			\$50.00
Impact Fee	Residential	\$315.00		
			<b>Total Due</b>	<b>\$50.00</b>

**Fee Notice:**

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Contact our offices at 801-782-3580 to arrange payments.

**Status: APPROVED WITH CONDITIONS**

**A Written Response Is Required. Please address each item.**

Items **HIGHLIGHTED** in yellow are items that must be specifically addressed by the responsible design professional.

*BOTH SPECIFIC AND GENERAL COMMENTS MUST BE READ AND ADHERED TO.*

**Specific Comments:**

**Water Supply:**

- S1. Water Supply Analysis Required: Prior to any construction being done, a water supply analysis shall be completed and submitted by an engineering firm or a fire protection engineer. This water supply analysis must include:
  - a. Building Construction Type
  - b. Available Water for fire-fighting purposes
    - i. Static Flow Rates
    - ii. Residual Flow Rates
    - iii. Flowing GPM
    - iv. Duration of flowing GPM available.
  - c. Statement of conformance/non-conformance to 2018 International Fire Code section 507 and Appendix B as adopted by Weber Fire District (See

**Chief, Paul Sullivan - Deputy Chief, Britt Clark - Fire Marshal, David Reed**



2023 West 1300 North  
Farr West Utah, 84404

Resolution 04-2014 at <http://weberfiredistrict.com/services/fire-prevention>).

- d. If deficiency exists, proposed method to obtain conformance with adopted codes and Resolution 04-2014.
- S2. Fire Flow: Fire flow for the residential subdivision shall be 2000 GPM.
- S3. Fire Hydrant(s): As per approved plans or two hydrants for each cluster. The maximum spacing between hydrants in a residential area is 500 ft.
- S4. All required fire hydrants and water systems shall be installed, approved and fully functional and on, prior to any combustible construction (IFC section 507.1 and 3312).

#### Fire Detection and Suppression Systems:

- S5. Fire Suppression Systems: Each unit will be equipped with a 13R fire suppression system.
- S6. SEPARATE SUBMITTAL NOTICE: Fire suppression systems and fire alarm systems require a separate submittal. A permit shall be applied for before any installation of either fire suppression system or fire alarm system. The permit shall be on the job site and be available for review by any inspector. The APPROVED STAMPED set of plans shall also be on the job site and available for review by any inspector. If there is no permit and/or approved stamped plans on the job site, there will be a Stop Work Order issued until both are on the job site. Submit plans at Weber Fire District, 2023 W. 1300 N. Farr West. (See IFC section 901.2 and 907.1.1).
- S7. Electronic Supervision and Alarms: Fire suppression system shall be electronically monitored. Monitoring shall include Valves; pumps; tanks; water levels and temperatures; critical air pressures; waterflow. Monitoring shall be electrically supervised by a *listed* fire alarm control unit (See IFC 903.4).
- S8. Exterior Notification Device: There shall be a weatherproof horn/strobe device located on the street side of the building or above the FDC as approved by the Fire Prevention Division (coordinate with fire inspector regarding location). Such sprinkler waterflow alarm devices shall be activated by water flow equivalent to the flow of a single sprinkler of the smallest orifice size installed in the system. (See IFC 903.4.2)
- S9. Fire Department Connections:
  - a. Locking Knox Fire Department Connection (FDC) caps are required for the FDC. These may be ordered at [www.knoxbox.com](http://www.knoxbox.com). Please select WEBER FIRE DISTRICT as your jurisdiction. (See IFC 912.4.1)
  - b. There shall be a cement pad measuring 3 ft. x 3 ft. under the FDC (coordinate with fire inspector regarding this). (See IFC 102.9)
  - c. Location: FDC connections shall be so located that fire apparatus and hose connected to supply the system will not obstruct access to the buildings for other fire apparatus. FDC locations shall be approved by the AHJ. (IFC 912.2)
  - d. Access: Immediate access to FDC shall be maintained always without obstruction from fences, trees, walls or other fixed or moveable object. (IFC 912.4)



2023 West 1300 North  
Farr West Utah, 84404

- e. Signs: A metal sign with raised letters not less than 1 inch in size shall be mounted on all fire department connections serving automatic sprinklers, standpipes, or fire pumps. Such signs shall read: "AUTOMATIC SPRINKLERS" or "STANDPIPES" or "TEST CONNECTION". (IFC 912.5)

#### Fire Department Access:

- S10. Provide a temporary address marker at the building site during construction. The address numbers, whether on the building or the sign, shall be legible font. (See IFC 505.1) (See IFC 505.1).
- S11. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width, and imposed loads as permanent roads (See IFC section 503.2.3; 3310; and D102.1).
- S12. Fire Access to buildings and facilities: Fire access roads are required for all facilities, buildings, or portions of buildings. Access roads shall extend to within 150 feet of all portions of the facility and all portions of the exterior walls of the first story of the building as measured by an approved route. (See IFC 503.1)
- S13. Fire Access via Driveways: Access roads shall have a minimum of 26 feet of drivable surface and a vertical clearance of 13 foot 6 inches and shall support a 75,000-pound load. If the road is less than 32 feet of drivable surface a no parking sign shall be placed on one or both sides. Driveways more than 150 feet shall be provided with turnarounds. Roads and driveways shall also comply with City/County standards as applicable. *In cases of differing requirements, contact the Fire Marshal for clarification.*
- S14. Gates:
  - a. Knox key switches are required for any electronic/electric gate. These may be ordered at [www.knoxbox.com](http://www.knoxbox.com). Please select WEBER FIRE DISTRICT as your jurisdiction. (See IFC 503.6)
  - b. Knox padlock is required for any manually operated mechanical gate. These may be ordered at [www.knoxbox.com](http://www.knoxbox.com). Please select WEBER FIRE DISTRICT as your jurisdiction. (See IFC 503.6)

#### Building Comments:

- S15. There shall be an address on the building or on a sign visible from the street. If the address is on a sign-monument the sign-monument shall meet the requirements of the appropriate city/county planning department. The address numbers, whether on the building or the sign, shall be Arabic font with a minimum of 4" (four inches) in height with a .5" (half inch) stroke and be in contrasting colors from the background. All suites shall have number/letter designation on the doors meeting the same size requirements and contrasting color. (See IFC 505.1)
- S16. Provide a working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height in front of electrical service equipment. If the electrical equipment is wider than 30 inches, the working space shall not be less than the width of the equipment. There shall be no storage within the designated working space. (See IFC 605.3)




2023 West 1300 North  
Farr West Utah, 84404

- S17. Doors into electrical control panel rooms shall be marked with plainly visible and legible sign stating, "ELECTRICAL ROOM". (See IFC 605.3.1)
- S18. Fire Protection and Utility Equipment Rooms:
- Rooms containing controls for air-conditioning systems, sprinkler risers and valves, fire detection or suppression shall be identified with a plainly visible and legible sign. (See IFC 509.1)
- S19. Gas meters shall be protected from vehicular damage. Above ground gas meters, regulators, and piping subject to damage shall be protected by bollards or barriers. (See IFC 603.9 and 312).
- S20. Fire doors shall have a permanent sign with 1-inch-high letters stating, "FIRE DOOR- DO NOT BLOCK". (See IFC 703.2.1)
- S21. A Knox Key Box is required for this building if it is alarmed. These may be ordered at [www.knoxbox.com](http://www.knoxbox.com). Please select WEBER FIRE DISTRICT as your jurisdiction. Only 3200 Series boxes shall be used. (See IFC 506.1)
- S22. Underground fire lines shall be flushed using a minimum 4-inch line. The end of the line shall be secured as to prevent injury or damage to person or property. The fire department shall witness the flush.
- S23. Underground thrust blocks shall be inspected prior to burial. Thrust blocks must meet the load bearing requirements of NFPA 24. Bag mix is not acceptable. Documentation from the supplier shall be submitted indicating the load bearing PSI rating of the concrete.

### **General Comments:**

- G1. Fire Access roads to any property shall have a minimum clear width of 20 feet (face of curb to face of curb) and a vertical clearance of 13 foot 6 inches and shall be capable of supporting a 75,000-pound load. Roads that are less than 26 feet in width shall be posted with "NO PARKING FIRE LANE" on both sides of the roadway. Roads more than 26 but less than 32 feet in width shall be posted on one side of the roadway. (Roadways and signage shall comply with appendix D of the 2018 International Fire Code as adopted by Weber Fire District).
- G2. Roads shall have a maximum grade of 10% unless specifically approved. Approval requires both the Fire Marshal's approval and Weber County Engineering approval (See IFC section 503.2.7; D103.2; and Weber County ordinances).
- G3. Radius on all corners shall be a minimum of 28'-0". Roads and driveways shall also comply with City/County standards as applicable. *In cases of differing requirements, contact the Fire Marshal for clarification.*
- G4. Roundabouts: Roundabouts in roadways shall maintain the required minimum width of 20 feet. Wider roadways may be required to provide turning radius for fire apparatus. An auto-turn model shall be completed and submitted for review. The following vehicle information shall be used for this purpose:
- Width: 12.0 Ft
  - Track: 7.61
  - Lock to Lock Time: 6.0





2023 West 1300 North  
Farr West Utah, 84404

d. Steering Angle: 41.3

- G5. Dead end fire apparatus access roads more than 150 feet in length shall be provided with an approved area for turning around fire apparatus constructed with the same requirements as the roads (See IFC section D103.4)
- G6. Roads and bridges shall be designed, constructed, and maintained to support an imposed load of 75,000 lbs. (See IFC section D102.1)
- G7. All roads shall be designed, constructed, surfaced, and maintained to provide an all-weather driving surface. All weather surfaces may include road-base material however, the roadway must be maintained open and accessible year-round (See IFC section 503.2.3 and D102.1).
- G8. Fire Prevention During Construction: The owner shall designate a person to be the fire prevention program superintendent who shall be responsible for the fire prevention program and ensure that it is carried out through completion of the project. Where guard service is provided, the superintendent shall be responsible for the guard service. The fire prevention program superintendent shall develop and maintain an approved pre-fire plan. The fire chief and the fire code official shall be notified of changes affecting the utilization of information contained in such pre-fire plans. (see IFC 3308)

This review was completed using the currently adopted Utah State Fire Code (International Fire Code) and any applicable local resolutions or ordinances.

Every effort has been made to provide a complete and thorough review of these plans. This review DOES NOT relieve the owner, contractor and/or developer from compliance with all applicable codes, and standards.

Any change or revision of this plan will render this review void and will require submittal of the new, or revised, layout for fire department review. If you have any questions, please contact me at 801-782-3580.

Reviewed By:  
David Reed, Fire Marshal  
Weber Fire District  
801-782-3580