



Date: 2/18/2022

Response memorandum for review comments received pertaining to **Buffalo Run Acres Subdivision**

Responses to additional Comments:

Sheet CE2-02

1. Added additional box for storm drain outfall to flow north and allow water to the south to bubble up if needed

Sheet CE2-06

1. Updated asphalt width to 36'