

Larry Slagkowski
Weber County Surveyor
2380 Washington Blvd. #240
Ogden, UT 84401

RE: Development Parcel D, Village Nests, Response to Surveyor's Comments

Mr. Slagkowski,

The following are comments and responses pertaining to the Village Nests Plat from your review and received on December 12, 2013.

Sheet 1:

1. Show dimensions on building configuration to match line tables to the 1/100th of a foot.
Response: Update building configurations to the 1/100th of a foot.
2. There are several issues with the ties between buildings, not were all checked, please insure correct and complete annotations.
Response: All annotations along buildings were check and corrected, per redlines.
3. See note on page 2 regarding tie to calculated monuments.
Response: removed calculated monuments and added swing tie from found section corners.
4. Please check building for private and LCA square footage.
Response: Checked and updated square footage of building on sheets 3 and 4, per redlines.

Sheet 2:


See previous comments above.

1. Village Nest Garage does not close.
Response: Fixed annotations.

Sheet 3 & 4:

See previous comments above.

Best Regards,



Richard Miller, PLS, Survey Manager

OFFICES NATIONWIDE