



June 9, 2022

Kirby Stephens  
2028 East 6225 South  
Uintah, Utah 84409

Dear Mr. Stephens,

You are hereby authorized to build your swimming pool up against the 10 foot PUE that runs through you property. The 46kV overhead power line is located within a centerline only easement with no defined width and no building restrictions. Keep in mind that you must still meet National Electric Safety Code and OSHA working clearance from the wires at all times. OSHA states that you cannot work within 10 feet of an energize 46kV power line.

If I can be of further assistance feel free to contact me at (801) 220-2212.

Thank You,

Scott C. Burton  
Sr. Project Sponsor  
Rocky Mountain Power