

BRIAN COWAN, MPH, LEHS  
Health Officer/Executive Director

July 28, 2022



Weber County Planning Commission  
2380 Washington Blvd.  
Ogden, UT 84401

RE: Preliminary Subdivision **Determination**  
Smith Estates Subdivision, 1 lots  
Parcel #21-008-0038  
Soil log #14790

Gentlemen:

The soil and percolation information for the above-referenced lot have been reviewed. Culinary water will be provided by a private well. **The placement of the well is critical so as to provide the required 100 foot protection zone.** The well will need to be dug, tested and the water supply approved prior to issuance of a wastewater disposal permit.

DESIGN REQUIREMENTS

Lot 1: Documented ground water tables not to exceed 48 inches, fall within the range of acceptability for a Packed Bed Media Treatment System followed by a conventional trench with a maximum trench depth limited to 18 inches. The absorption system is to be designed using a maximum loading rate of 0.35gal/sq. ft. /day as required for a gravelly sandy clay, massive structure soil with a documented percolation rate of 96-120 minute per inch. The absorption field must be located within 50 feet of test pit #2 (UTM Zone 12T, Nad 83, 435643E 4568905N) or test pit #3 (UTM Zone 12T, Nad 83, 435622E 4568908N).

Plans for the construction of any wastewater disposal system are to be prepared by a Utah State certified individual and submitted to this office for review prior to the issuance of a Wastewater Disposal permit.

The following items are required for a formal subdivision review; application, receipt of the appropriate fee, and a full sized copy of the subdivision plats showing the location of exploration pits and percolation tests as well as the documented soil horizons and percolation rates. A subdivision review will not occur until all items are submitted. Mylars submitted for signature without this information will be returned.

Each on-site individual wastewater disposal system must be installed in accordance with R317-4, Utah Administrative Code, Individual Wastewater Disposal Systems and Weber-Morgan District Health Department Rules. Final approval will be given only after an on-site inspection of the completed project and prior to the accomplishment of any backfilling.

Please be advised that the conditions of this letter are valid for a period of 18 months. At that time, the site will be re-evaluated in relation to rules in effect at that time.

Sincerely,

  
Summer Day, LEHS III, Program Manager  
Environmental Health Division  
801-399-7160

EDUCATE | ENGAGE | EMPOWER