



January 2, 2014

Brandon Thueson
Fire Marshal
Weber Fire District

RE: Cardon Subdivision Culvert

SUBJECT:

Gardner Engineering is providing Engineering recommendations and conclusions regarding the load limits of the as constructed culvert on the Cardon Subdivision access road.

CONCLUSION:

The H-20 Pipe as installed exceeds the required 75,000 lb. load requirement for a vehicle with more than four (4) wheels.

Please let me know if you have any questions or need any additional information.

Thank you,

Klint H. Whitney P.L.S.
Gardner Engineering