

The Villas at JDC Ranch

Preapplication Meeting Notes

August 24th, 2023

Discussion Topics/Tasks

- Trail Location and size along 2725 North
- 5' sidewalk minimum required
- Common area to be designated as a public utility easement
- On side of street with trail, place meters behind trail.