

Subdivision  
Water Supply  
Applicant  
Mailing Address  
City

In consideration of wastewater disposal

1. I shall
2. Department
3. If the
4. I understand

I UNDERSTAND AND AGREE TO THE TERMS AND CONDITIONS OF THIS PERMIT.  
Applicant

**PERMIT TO CONSTRUCT AN INDIVIDUAL WASTEWATER DISPOSAL SYSTEM  
ISSUED BY THE WEBER-MORGAN DISTRICT HEALTH DEPARTMENT  
2570 GRANT AVE., OGDEN, UTAH 84401**

HEALTH DEPARTMENT

Issued: July 6, 2006 Expires: July 6, 2007

BRYNER is hereby issued a permit to install an individual wastewater disposal system for the property with the following specifications and provisions:

Address: 11768 E SUNRIDGE CIR, HUNTSVILLE  
Division in Weber county Utah.  
Location: SUNRIDGE HIGHLANDS.  
Absorption Field with an absorption area of 330 Sq. Ft.  
System is designed for a 2 bedroom home.  
Flow capacity must be limited to 1000 gallons.  
Tank must be limited to 36 inches from original ground surface.

**IMPORTANT - PLEASE READ CAREFULLY** \* \* \*

DEPTH OF TRENCH FROM ORIGINAL GROUND SURFACE IS 36 INCHES.  
CONSTRUCTION PLANS REVIEWED BY THIS OFFICE.  
TANK REQUIRED. TANK MUST BE FULL AT TIME OF INSPECTION.

Permittee shall be responsible for providing the final inspection or any additional information regarding this system.  
prior to any backfilling of installed system.

Permit is based on minimum design standards. This permit is based on minimum design standards. The performance of the installed system is affected by many factors, including but not limited to, soil conditions, groundwater levels, and other site specific conditions. The permittee is responsible for ensuring that the system is installed and maintained in accordance with the standards.

**FINAL APPROVAL OF INDIVIDUAL WASTEWATER SYSTEM**

WEBER-MORGAN  
HEALTH DEPARTMENT

23rd Street  
Ogden, Utah 84401  
OFFICE (801) 399-7160  
FAX (801) 399-7170

July 14, 2006

GORDON BRYNER  
409 W 1500 N  
HARRISVILLE, UT 84404-

Permit No. W100420      **ABSORPTION FIELD**

This is to certify that on **July 12, 2006** the Weber-Morgan Health Department made a final inspection of the individual wastewater disposal system installed at the construction site address of: **11768 E SUNRIDGE CIR** in **WEBER COUNTY, UTAH**.

At the time of the final inspection, the wastewater system was found to be in compliance with the requirements of the Weber-Morgan Health Department. Approval to place the above-referenced wastewater system into service is hereby granted to **GORDON BRYNER**.

This individual wastewater disposal system will require periodic maintenance to keep the system working properly. In addition, care must be taken not to disturb or damage the **ABSORPTION FIELD**. The attached document will provide you with information on the proper care and maintenance of this wastewater disposal system.

If you have any questions or need further assistance please contact this office at (801) 399-8381.

Brian Cowan *jc*  
Representative, Weber-Morgan Health Department

