



Weber Fire District

Plan Review

Date: June 11, 2014

Project Name: Mitch Painter Subdivision

Project Address: 1779 S 3550 W, Ogden

Contractor/Contact: Phil Hancock 801-435-2045

Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Residential			\$50.00
Residential Impact Fee	328.15		1	\$328.15
				\$0.00
				\$0.00
			Total Due	\$378.15

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. *Impact Fees are due prior to taking out a building permit.* Make checks payable to: **Weber Fire District.**

REVIEW STATUS: MAKE CORRECTIONS

SPECIFIC COMMENTS:

1. The plat indicates that the lot and remaining parcel are located at 3500 West and 3500 West? The description within Lot 1 simply states "ADDRESS" but does not provide the address itself. The correct address location needs to be shown.
2. Fire Hydrant(s): The small detail indicates an existing fire hydrant located wouth of the property. What is the distance from the hydrant to the lot?
3. There must be a fire hydrant within 250 feet of the building lot. If this distance is not met by the existing hydrant, then a new hydrant shall be provided. The maximum spacing between hydrants in a residential area is 500 ft.
4. Fire Flow: All structures over 5000 sq. ft. which do not meet the fire flow requirements, shall be equipped with an NFPA 13D compliant fire sprinkler system. For more information regarding fire flow, please contact Fire Marshal Thueson at 801-782-3580.
5. Provide a temporary address marker at the building site during construction.

General Requirements:

- Roads and bridges shall be designed, constructed and maintained to support an imposed load of 75,000 lbs.
- All roads shall be designed, constructed, surfaced and maintained so as to provide an all-weather driving surface.
- Fire access roads for this project shall be completed and approved prior to any



Weber Fire District

Plan Review

combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.

- All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
- Fire department apparatus access is required for each lot.

A written response for this review is required.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson
Fire Marshal

cc: File