



Weber Fire District

Plan Review

Date: May 21, 2014

Project Name: Henry Flats Cluster Subdivision

Project Address: 4300 W 400 S West Weber Utah

Contractor/Contact: Travis Wallace 801-540-9011

Fees:

Property Type	Schedule Rates	Square Foot Rate	Square Feet or Number of Res. Units	Total
Type	Rate	Rate/ Sq Ft	Sq Ft or # of Units	Total
Plan Review	Subdivision 1-30 Lots			\$50.00
			Total Due	\$50.00

FEE NOTICE:

Weber Fire District has various fees associated with plan reviews, and inspections. Please be prepared to make payments at the time of inspections or when you pick up your approved plans. Impact Fees are due prior to taking out a building permit. Make checks payable to: **Weber Fire District.**

REVIEW STATUS: APPROVED

SPECIFIC COMMENTS:

1. Public and private roads within subdivisions shall have a minimum clear and unobstructed width of twenty six feet. Roads shall have a minimum clear and unobstructed height of 13'-6" and shall be capable of supporting a 75,000 pound load.
2. Roads shall have a maximum grade of 10% unless specifically approved as outlined by the International Fire Code.
3. Radius on all corners shall be a minimum of 28'-0".
4. Fire access roads for this project shall be completed and approved prior to any combustible construction. Temporary roads shall meet the same requirements for height, width and imposed loads as permanent roads.
5. All required fire hydrants and water systems shall be installed, approved and fully functional prior to any combustible construction.
6. All structures over 5000 sq. ft. which do not meet the fire flow requirements, shall be equipped with an NFPA compliant fire sprinkler system.

A written response for this review is required.

Every effort has been made to provide a complete and thorough review of these plans. This review does not relieve the owner, contractor and/or developer from compliance with any and all applicable codes and standards. Any change or revision of this plan will render this review void



Weber Fire District

Plan Review

and will require submittal of the new or revised layout for fire department review.

Reviewed by: Brandon Thueson
Fire Marshal

cc: File