



PERCOLATION TESTS

Date: 04-10-14
 Name of Client: Travis Wallace, 6272-01
 Location of Property: Henry Flats - Residential Subdivision, 400 S 4300 W, Weber County,
 Evaluation Number 14027.
 Depth to Water Table / Soil Conditions: Ground water was encountered and measured matching the County March 26 depths.

I hereby certify to the best of my knowledge that percolation tests have been conducted on the above property in accordance with requirements specified in R317, Utah Administrative Code, and that percolation rates, calculated as specified by said rule, are as follows:

Test Pit #	Perc. Test Depth	Test Hole Diameter (in)	Time Interval Used for Drop	Final Stabilized Percolation Rate Minutes/Inch
2	36"	8	30 Minutes	53.33
		8	30 Minutes	53.33
5	36"	8	30 Minutes	53.33
		8	30 Minutes	53.33
7	36"	8	30 Minutes	40.00
		8	30 Minutes	40.00
8	36"	8	30 Minutes	40.00
		8	30 Minutes	40.00
13	36"	8	30 Minutes	53.33
		8	30 Minutes	53.33

J. Nate Reeve, P.E.